



**CMA Testing  
and Certification  
Laboratories**

廠商會檢定中心

**Term Contract for Provision of Sampling and Analyzing of  
Wastewater and Sludge for Various Sewage Treatment Facilities in  
Urban Area, Lantau and Outlying Islands to the  
Drainage Services Department**

Contract No. : DE/2016/12

Applicant : SEWAGE TREATMENT DIVISION 2  
ELECTRICAL AND MECHANICAL BRANCH  
DRAINAGE SERVICES DEPARTMENT

Address : STONECUTTERS ISLAND SEWAGE TREATMENT WORKS.,  
NGONG SHUNG ROAD, NGONG SHUEN CHAU,  
KOWLOON, HONG KONG

Application Number : LV034607(9)

Report Number : AW0016391(9)

Report Issued Date : 16 Mar 2018

*For and on behalf of*

CMA Industrial Development Foundation Limited

Authorized Signature : \_\_\_\_\_

Lau Yan Kin  
Senior Manager  
Environmental Division

This document is issued subject to the latest CMA Testing General Terms and Conditions of Testing and Inspection Services, available on request or accessible at website [www.cmatcl.com](http://www.cmatcl.com)  
This document shall not be reproduced except in full or with written approval by CMA Testing

CMA Industrial Development Foundation Limited

Room 1302, Yan Hing Centre, 9-13 Wong Chuk Yeung St., Fo Tan, Shatin, N.T., Hong Kong.

Tel: (852) 2698 8198 Fax: (852) 2695 4177 E-mail: [info@cmatcl.com](mailto:info@cmatcl.com) Web Site: <http://www.cmatcl.com>



# CMA Testing and Certification Laboratories

廠商會檢定中心

Report No.: AW0016391(9)

Term Contract for Provision of Sampling and Analyzing of Wastewater and Sludge Samples for Various and Sludge Samples for Various Sewage Treatment Facilities in Urban Area, Lantau and Outlying Islands to the Drainage Services Department

---

## TABLE OF CONTENT

---

1. Introduction	2
2. Effluent Quality Monitoring	3 – 4
3. Results and Observations	4

### Appendix

Appendix I – Report for Laboratory Test(s)



# CMA Testing and Certification Laboratories

廠商會檢定中心

Report No.: AW0016391(9)

Term Contract for Provision of Sampling and Analyzing of Wastewater  
and Sludge Samples for Various Sewage Treatment Facilities in Urban Area, Lantau and Outlying Islands to  
the Drainage Services Department

---

## EXECUTIVE SUMMARY

1. This is the water quality monitoring report prepared by CMA Testing and Certification Laboratory (CMA Testing) for Contract No. DE/2016/12 “Term Contract for Provision of Sampling and analysing of Wastewater and Sludge Samples for Various Sewage Treatment Facilities in Urban Area, Lantau and Outlying Islands to the Drainage Services Department (2017-2019)”. This report documented the results and findings of Operation Phase Environmental Monitoring works conducted for Effluent Quality Monitoring (EQM) of Project in Jan 2018.
2. In accordance with the Final EM&A Manual, environmental monitoring has been conducted in the reporting month with a Quarterly Basis for various parameters as summarized in **Table I**.

**Table I Summary Table for Environmental Monitoring Works Conducted in the Reporting Month**

Monitoring Parameters	Monitoring Date	Laboratory Testing Parameters
Effluent Quality	23 Jan 2018 to 24 Jan 2018	Chlorination by-products (CBPs) and Contaminants of Concern (COCs)



# CMA Testing and Certification Laboratories

廠商會檢定中心

Report No.: AW0016391(9)

Term Contract for Provision of Sampling and Analyzing of Wastewater  
and Sludge Samples for Various Sewage Treatment Facilities in Urban Area, Lantau and Outlying Islands to  
the Drainage Services Department

---

## 1. INTRODUCTION

- 1.1. CMA Testing was commissioned by Drainage Services Department (DSD) to undertake the operation phase environmental monitoring for Advance Disinfection Facilities (ADF) at Stonecutters Island Sewage Treatment Works (SCISTW) (thereafter called the “the Services”).
- 1.2. The operation phase monitoring, which include effluent quality monitoring, marine water quality monitoring and emergency discharge monitoring, is to monitor the effluent and marine water quality impact of ADF during its operation phase.
- 1.3. This is the water quality monitoring report prepared by CMA Testing that documented the results and findings of Operation Phase Water Quality Monitoring works conducted for Effluent Quality Monitoring (EQM) of Project on 23 Jan 2018 to 24 Jan 2018.



# CMA Testing and Certification Laboratories

廠商會檢定中心

Report No.: AW0016391(9)

Term Contract for Provision of Sampling and Analyzing of Wastewater and Sludge Samples for Various Sewage Treatment Facilities in Urban Area, Lantau and Outlying Islands to the Drainage Services Department

## 2. EFFLUENT QUALITY MONITORING

### Monitoring Requirements

- 2.1. Effluent samples were collected at Disinfection Facilities in a full 24-hour period. 24-hour flow weighted composite effluent samples for subsequent chemical analysis and testing were prepared by CMA according to the following procedures:
  - Collect effluent sub-sample by direct grab sampling method at bi-hourly interval over a 24 hour period;
  - Obtain flow record of Stonecutters Island Sewage Treatment Works (SCISTW) for the 24-hour sampling period;
  - Calculate the volume of each sub-sample for preparation the bi-hourly of 24 hour flow-weighted composite samples; and
  - Transfer the appropriate the volume of sub-samples to a clean container and mix thoroughly.
- 2.2. Chlorination By-Products (CBPs) and Contaminants of Concern (COCs) shall be performed quarterly throughout the contract period.

### Monitoring Location

- 2.3. The sampling locations for effluent from SCISTW were collected at the Disinfection Facilities

### Monitoring Schedule

- 2.4. The effluent quality monitoring was conducted between the time periods of 10:00am 23 Jan 2018 to 10:00am of 24 Jan 2018 in the reporting month. Collection of marine water samples were within the time period of effluent quality monitoring was to be collected.

### Laboratory Measurement / Analysis

- 2.5. In the reporting month, the bi-hourly of 24-hour flow-weighted composite effluent sample was collected for subsequent laboratory analysis and testing on CBPs and COCs as shown in **Table 2.1**.

**Table 2.1 Analytical Methods for Laboratory Analysis for Effluent Samples**

Parameters		Analytical Method	Limit of Reporting (µg/L)
<b>Potential CBPs</b>			
Bromoform	Tri-halomethanes (THMs)	TG-ENV-WW-78 (Headspace GC-MS)	0.1
Bromodichloromethane			0.1
Chloroform			0.1
Dibromochloromethane			5
Bromoacetic acid	Haloacetic Acids (HAAs)	TG-ENV-WW-79 (GC-ECD)	2
Chloroacetic acid			2



# CMA Testing and Certification Laboratories

廠商會檢定中心

Report No.: AW0016391(9)

Term Contract for Provision of Sampling and Analyzing of Wastewater and Sludge Samples for Various Sewage Treatment Facilities in Urban Area, Lantau and Outlying Islands to the Drainage Services Department

Dibromoacetic acid			2
Dichloroacetic acid			2
Trichloroacetic acid			2
<b>Contaminants of Concern (COCs)</b>			
Methylene chloride	Halogenated Aliphatics	TG-ENV-WW-78 (Headspace GC-MS)	20
Carbon tetrachloride			0.5
1,1-dichloroethane			0.5
1,2-dichloroethane			0.5
1,1-dichloroethylene			0.5
1,2-dichloropropane			0.5
Tetrachloroethylene			0.5
1,1,1-trichloroethane	Halogenated Aliphatics		0.5
1,1,2-trichloroethane			0.5
Trichloroethylene			0.5
2-chlorophenol	Phenols & Haloethers	TG-ENV-WW-80 (GC-MS)	0.5
2,4-dichlorophenol			0.5
p-chloro-m-cresol			0.5
Pentachlorophenol			0.5
2,4,6-trichlorophenol			0.5
Bis(2-chloroethoxy) methane			0.5
Chlorobenzene			
1,4-dichlorobenzene	0.5		
Hexachlorobenzene	Chlorinated Hydrocarbons & Organochlorine Pesticides	USEPA 625	0.01
Hexachlorocyclopentadiene			2.5
Hexachloroethane			0.5
1,2,4-trichlorobenzene			0.5
Alpha-BHC			0.01
Beta-BHC			0.01
Gamma-BHC			0.01

### 3. RESULTS AND OBSERVATIONS

#### Effluent Quality

- 3.1. The results of effluent quality monitoring conducted on the time period of 10:00am 23 Jan 2018 to 10:00am of 24 Jan 2018, whereas the laboratory testing and QC report are shown in **Appendix I- Report no. AW0016390(8)**.



# CMA Testing and Certification Laboratories

廠商會檢定中心

Report No.: AW0016391(9)

Term Contract for Provision of Sampling and Analyzing of Wastewater  
and Sludge Samples for Various Sewage Treatment Facilities in Urban Area, Lantau and Outlying Islands to  
the Drainage Services Department

---

## Appendix I - Report for Laboratory Test(s)



# CMA Testing and Certification Laboratories

廠商會檢定中心

## TEST REPORT

Report No. : AW0016390(8) Date: 16 Mar 2018

Application No. : LV034607(9)

Applicant : SEWAGE TREATMENT DIVISION 2  
ELECTRICAL AND MECHANICAL BRANCH  
DRAINAGE SERVICES DEPARTMENT  
STONECUTTERS ISLAND SEWAGE TREATMENT WORKS.,  
NGONG SHUNG ROAD, NGONG SHUEN CHAU,  
KOWLOON, HONG KONG

Contract No. : DE/2016/12

Project Name : Term Contract for Provision of Sampling and Analyzing of  
Wastewater and Sludge for Various Sewage Treatment Facilities in  
Urban Area, Lantau and Outlying Islands to the Drainage Services  
Department

Sample Description : One (1) wastewater sample sampled by the staff of CMA Industrial  
Development Foundation Limited.  
Sample was refrigerated during delivery.

Sample ID : Refer to Sample ID on page 4.

Sampling Location : SCISTW- Disinfection Facilities

Sampling Date : 23 Jan 2018 to 24 Jan 2018.

Date Received : 24 Jan 2018.

Test Period : 24 Jan 2018 to 26 Feb 2018.

*For and on behalf of*  
CMA Industrial Development Foundation Limited

Authorized Signature :

  
\_\_\_\_\_  
Lau Yan Kin  
Senior Manager  
Environmental Division

Page 1 of 5

CMA Industrial Development Foundation Limited

Room 1302, Yan Hing Centre, 9-13 Wong Chuk Yeung St., Fo Tan, Shatin, N.T., Hong Kong.

Tel: (852) 2698 8198 Fax: (852) 2695 4177 E-mail: [info@cmatcl.com](mailto:info@cmatcl.com) Web Site: <http://www.cmatcl.com>





# CMA Testing and Certification Laboratories

廠商會檢定中心

## TEST REPORT

Report No. : AW0016390(8)

Date: 16 Mar 2018

Application No. : LV034607(9)

Test Requested :

1. Bromoform
2. Bromodichloromethane
3. Chloroform
4. Dibromochloromethane
5. Bromoacetic acid
6. Chloroacetic acid
7. Dibromoacetic acid
8. Dichloroacetic acid
9. Trichloroacetic acid
10. Methylene chloride
11. Carbon tetrachloride
12. 1,1-dichloroethane
13. 1,2-dichloroethane
14. 1,1-dichloroethylene
15. 1,2-dichloropropane
16. Tetrachloroethylene
17. 1,1,1-trichloroethane
18. 1,1,2-trichloroethane
19. Trichloroethylene
20. 2-chlorophenol
21. 2,4-dichlorophenol
22. p-chloro-m-cresol
23. Pentachlorophenol
24. 2,4,6-trichlorophenol
25. Bis(2-chloroethoxy) methane
26. Chlorobenzene
27. 1,4-dichlorobenzene
28. Hexachlorobenzene
29. Hexachlorocyclopentadiene
30. Hexachloroethane
31. 1,2,4-trichlorobenzene
32. Alpha-BHC
33. Beta-BHC
34. Gamma-BHC



# CMA Testing and Certification Laboratories

廠商會檢定中心

## TEST REPORT

Report No. : AW0016390(8)

Date: 16 Mar 2018

Application No. : LV034607(9)

Test Method : 1. TG-ENV-WW-78 (Headspace GC-MS)  
2. TG-ENV-WW-78 (Headspace GC-MS)  
3. TG-ENV-WW-78 (Headspace GC-MS)  
4. TG-ENV-WW-78 (Headspace GC-MS)  
5. TG-ENV-WW-79 (GC-ECD)  
6. TG-ENV-WW-79 (GC-ECD)  
7. TG-ENV-WW-79 (GC-ECD)  
8. TG-ENV-WW-79 (GC-ECD)  
9. TG-ENV-WW-79 (GC-ECD)  
10. TG-ENV-WW-78 (Headspace GC-MS)  
11. TG-ENV-WW-78 (Headspace GC-MS)  
12. TG-ENV-WW-78 (Headspace GC-MS)  
13. TG-ENV-WW-78 (Headspace GC-MS)  
14. TG-ENV-WW-78 (Headspace GC-MS)  
15. TG-ENV-WW-78 (Headspace GC-MS)  
16. TG-ENV-WW-78 (Headspace GC-MS)  
17. TG-ENV-WW-78 (Headspace GC-MS)  
18. TG-ENV-WW-78 (Headspace GC-MS)  
19. TG-ENV-WW-78 (Headspace GC-MS)  
20. TG-ENV-WW-80 (GC-MS)  
21. TG-ENV-WW-80 (GC-MS)  
22. TG-ENV-WW-80 (GC-MS)  
23. TG-ENV-WW-80 (GC-MS)  
24. TG-ENV-WW-80 (GC-MS)  
25. TG-ENV-WW-80 (GC-MS)  
26. TG-ENV-WW-78 (Headspace GC-MS)  
27. TG-ENV-WW-78 (Headspace GC-MS)  
28. USEPA 625  
29. USEPA 625  
30. USEPA 625  
31. USEPA 625  
32. USEPA 625  
33. USEPA 625  
34. USEPA 625

Test Result : Refer to results on page 4.



# CMA Testing and Certification Laboratories

廠商會檢定中心

## TEST REPORT

Report No. : AW0016390(8)

Date: 16 Mar 2018

Application No. : LV034607(9)

### Effluent Water Quality

Application No.: LV034607  
Sampling Date: 23-Jan-18 to 24-Jan-18  
Monitoring Location: Chamber 15A

#### Composite Sample

Parameter	Results (µg/L)
Bromoform	3.1
Bromodichloromethane	1.3
Chloroform	12.3
Dibromochloromethane	<5
Bromoacetic acid	<2
Chloroacetic acid	<2
Dibromoacetic acid	3.0
Dichloroacetic acid	14.4
Trichloroacetic acid	7.7

Parameter	Results (µg/L)
Methylene chloride	<20
Carbon tetrachloride	<0.5
1,1-dichloroethane	<0.5
1,2-dichloroethane	<0.5
1,1-dichloroethylene	<0.5
1,2-dichloropropane	<0.5
Tetrachloroethylene	<0.5
1,1,1-trichloroethane	<0.5
1,1,2-trichloroethane	<0.5
Trichloroethylene	<0.5
2-chlorophenol	<0.5
2,4-dichlorophenol	<0.5
p-chloro-m-cresol	<0.5
Pentachlorophenol	<0.5
2,4,6-trichlorophenol	<0.5
Bis(2-chloroethoxy) methane	<0.5
Chlorobenzene	<0.5
1,4-dichlorobenzene	<0.5
Hexachlorobenzene	<0.01
Hexachlorocyclopentadiene	<2.5
Hexachloroethane	<0.5
1,2,4-trichlorobenzene	<0.5
Alpha-BHC	<0.01
Beta-BHC	<0.01
Gamma-BHC	<0.01

# TEST REPORT

Report No. : AW0016390(8)

Date: 16 Mar 2018

Application No. : LV034607(9)


## QC Report

Sampling Date 23-Jan-2018

Parameter	Method Blank (µg/L)	Acceptance Criteria (µg/L)	QC Recovery (%)	Acceptance Criteria (%)	Spike Recovery (%)	Acceptance Criteria (%)	Duplicate (RPD) (%)	Acceptance Criteria (%)
Bromoform	<0.02	<0.02	107	80-120	104	70-130	8	≤20
Bromodichloromethane	<0.02	<0.02	93	80-120	92	70-130	8	≤20
Chloroform	<0.02	<0.02	96	80-120	87	70-130	4	≤20
Dibromochloromethane	<1	>1	105	80-120	89	70-130	6	≤20
Bromoacetic acid	<0.4	<0.4	98	80-120	97	70-130	9	≤20
Chloroacetic acid	<0.4	<0.4	92	80-120	105	70-130	4	≤20
Dibromoacetic acid	<0.4	<0.4	97	80-120	106	70-130	3	≤20
Dichloroacetic acid	<0.4	<0.4	101	80-120	84	70-130	7	≤20
Trichloroacetic acid	<0.4	<0.4	95	80-120	98	70-130	5	≤20

Parameter	(µg/L)	(µg/L)	(%)	(%)	(%)	(%)	(%)	(%)
Methylene chloride	<4	>4	94	80-120	95	70-130	6	≤20
Carbon tetrachloride	<0.1	<0.1	93	80-120	91	70-130	3	≤20
1,1-dichloroethane	<0.1	<0.1	108	80-120	97	70-130	8	≤20
1,2-dichloroethane	<0.1	<0.1	108	80-120	96	70-130	7	≤20
1,1-dichloroethylene	<0.1	<0.1	91	80-120	102	70-130	4	≤20
1,2-dichloropropane	<0.1	<0.1	97	80-120	101	70-130	3	≤20
Tetrachloroethylene	<0.1	<0.1	96	80-120	97	70-130	9	≤20
1,1,1-trichloroethane	<0.1	<0.1	92	80-120	106	70-130	6	≤20
1,1,2-trichloroethane	<0.1	<0.1	98	80-120	95	70-130	4	≤20
Trichloroethylene	<0.1	<0.1	103	80-120	103	70-130	5	≤20
2-chlorophenol	<0.1	<0.1	95	80-120	86	70-130	3	≤20
2,4-dichlorophenol	<0.1	<0.1	107	80-120	85	70-130	9	≤20
p-chloro-m-cresol	<0.1	<0.1	104	80-120	106	70-130	7	≤20
Pentachlorophenol	<0.1	<0.1	107	80-120	107	70-130	6	≤20
2,4,6-trichlorophenol	<0.1	<0.1	96	80-120	93	70-130	3	≤20
Bis(2-chloroethoxy) methane	<0.1	<0.1	92	80-120	86	70-130	4	≤20
Chlorobenzene	<0.1	<0.1	95	80-120	95	70-130	5	≤20
1,4-dichlorobenzene	<0.1	<0.1	97	80-120	106	70-130	5	≤20
Hexachlorobenzene	<0.005	<0.005	99	80-120	109	70-130	8	≤20
Hexachlorocyclopentadiene	<0.5	<0.5	107	80-120	89	70-130	3	≤20
Hexachloroethane	<0.1	<0.1	104	80-120	95	70-130	9	≤20
1,2,4-trichlorobenzene	<0.1	<0.1	102	80-120	94	70-130	4	≤20
Alpha-BHC	<0.005	<0.005	106	80-120	103	70-130	2	≤20
Beta-BHC	<0.005	<0.005	105	80-120	84	70-130	6	≤20
Gamma-BHC	<0.005	<0.005	108	80-120	98	70-130	7	≤20

\*\*\*\*\* End of Report \*\*\*\*\*



**CMA Testing  
and Certification  
Laboratories**  
 廠商會檢定中心