



**CMA Testing  
and Certification  
Laboratories**

廠商會檢定中心

**Term Contract for Provision of Sampling and Analyzing of  
Wastewater and Sludge Samples for Various Sewage Treatment  
Facilities add Marine Water Samples in Urban Area, Lantau and  
Outlying Islands to the Drainage Service Department**

**Provision of Effluent Quality Monitoring (EQM) Services**

**Report for the Month of Apr 2019**

Contract No. : DE/2018/02

Applicant : SEWAGE TREATMENT DIVISION 2  
ELECTRICAL AND MECHANICAL BRANCH  
DRAINAGE SERVICES DEPARTMENT

Address : STONECUTTERS ISLAND SEWAGE TREATMENT WORKS.,  
NGONG SHUNG ROAD, NGONG SHUEN CHAU,  
KOWLOON, HONG KONG


Application Number : LY012826(8)

Report Number : AY0026486(4)

Report Issued Date : 23 May 2019

For and on behalf of  
CMA Industrial Development Foundation Limited

Authorized Signature : \_\_\_\_\_

  
Lau Yan Kin  
Senior Manager  
Environmental Division



# CMA Testing and Certification Laboratories

廠商會檢定中心

Report No.: AY0026486(4)

Term Contract for Provision of Sampling and Analyzing of Wastewater and Sludge Samples for Various and Sludge Samples for Various Sewage Treatment Facilities and Marine Water Samples in Urban Area, Lantau and Outlying Islands to the Drainage Services Department

---

## TABLE OF CONTENT

---

1. Introduction	2
2. Effluent Quality Monitoring	3 – 4
3. Results and Observations	4
Appendix	
Appendix I	– Report for Laboratory Test(s)



# CMA Testing and Certification Laboratories

廠商會檢定中心

Report No.: AY0026486(4)

Term Contract for Provision of Sampling and Analyzing of Wastewater  
and Sludge Samples for Various Sewage Treatment Facilities and Marine Water Samples in Urban Area,  
Lantau and Outlying Islands to the Drainage Services Department

---

## EXECUTIVE SUMMARY

1. This is the water quality monitoring report prepared by CMA Testing and Certification Laboratory (CMA Testing) for Contract No. DE/2018/02 ‘Term Contract for Provision of Sampling and analysing of Wastewater and Sludge Samples for Various Sewage Treatment Facilities and Marine Water Samples in Urban Area, Lantau and Outlying Islands to the Drainage Services Department (2018-2020)’. This report documented the results and findings of Operation Phase Environmental Monitoring works conducted for Effluent Quality Monitoring (EQM) of Project in Apr 2019.
2. In accordance with the Final EM&A Manual, environmental monitoring has been conducted in the reporting month with a Quarterly Basis for various parameters as summarized in **Table I**.

**Table I Summary Table for Environmental Monitoring Works Conducted in the Reporting Month**

Monitoring Parameters	Monitoring Date	Laboratory Testing Parameters
Effluent Quality	26 Apr 2019 to 27 Apr 2019	Total Residual Chlorine (TRC) Chlorination by-products (CBPs) and Contaminants of Concern (COCs)



# CMA Testing and Certification Laboratories

廠商會檢定中心

Report No.: AY0026486(4)

Term Contract for Provision of Sampling and Analyzing of Wastewater  
and Sludge Samples for Various Sewage Treatment Facilities and Marine Water Samples in Urban Area,  
Lantau and Outlying Islands to the Drainage Services Department

---

## 1. INTRODUCTION

- 1.1. CMA Testing was commissioned by Drainage Services Department (DSD) to undertake the operation phase environmental monitoring for Advance Disinfection Facilities (ADF) at Stonecutters Island Sewage Treatment Works (SCISTW) (thereafter called the “the Services”).
- 1.2. The operation phase monitoring, which include effluent quality monitoring, marine water quality monitoring and emergency discharge monitoring, is to monitor the effluent and marine water quality impact of ADF during its operation phase.
- 1.3. This is the water quality monitoring report prepared by CMA Testing that documented the results and findings of Operation Phase Water Quality Monitoring works conducted for Effluent Quality Monitoring (EQM) of Project on 26 Apr 2019 to 27 Apr 2019.



# CMA Testing and Certification Laboratories

廠商會檢定中心

Report No.: AY0026486(4)

Term Contract for Provision of Sampling and Analyzing of Wastewater  
and Sludge Samples for Various Sewage Treatment Facilities and Marine Water Samples in Urban Area,  
Lantau and Outlying Islands to the Drainage Services Department

---

## 2. EFFLUENT QUALITY MONITORING

### Monitoring Requirements

- 2.1. Effluent samples were collected at Disinfection Facilities in a full 24-hour period. 24-hour flow weighted composite effluent samples for subsequent chemical analysis and testing were prepared by CMA according to the following procedures:
  - Collect effluent sub-sample by direct grab sampling method at bi-hourly interval over a 24 hour period;
  - Obtain flow record of Stonecutters Island Sewage Treatment Works (SCISTW) for the 24-hour sampling period;
  - Calculate the volume of each sub-sample for preparation the bi-hourly of 24 hour flow-weighted composite samples; and
  - Transfer the appropriate the volume of sub-samples to a clean container and mix thoroughly.
- 2.2. Bi-hourly of 24-hour composite sample for Total Residual Chloride (TRC), Chlorination By-Products (CBPs) and Contaminants of Concern (COCs) tests shall be performed quarterly throughout the contract period.

### Monitoring Location

- 2.3. The sampling locations for effluent from SCISTW were collected at the Disinfection Facilities

### Monitoring Schedule

- 2.4. The effluent quality monitoring was conducted between the time periods of 10:00am 26 Apr 2019 to 10:00am of 27 Apr 2019 in the reporting month. Collection of marine water samples were within the time period of effluent quality monitoring was to be collected.

### Laboratory Measurement / Analysis

- 2.5. In the reporting month, the bi-hourly of 24-hour flow-weighted composite effluent sample was collected for subsequent laboratory analysis and testing on TRC, CBPs and COCs as shown in **Table 2.1**.



# CMA Testing and Certification Laboratories

廠商會檢定中心

Report No.: AY0026486(4)

Term Contract for Provision of Sampling and Analyzing of Wastewater and Sludge Samples for Various Sewage Treatment Facilities and Marine Water Samples in Urban Area, Lantau and Outlying Islands to the Drainage Services Department

**Table 2.1 Analytical Methods for Laboratory Analysis for Effluent Samples**

Parameters		Analytical Method	Limit of Reporting (µg/L)
<b>TRC and Potential CBPs</b>			
Total residual Chlorine		APHA 21ed 4500 Cl G	10
Bromoform	Tri-halomethanes (THMs)	TG-ENV-WW-78 (Headspace GC-MS)	0.1
Bromodichloromethane			0.1
Chloroform			0.1
Dibromochloromethane			5
Bromoacetic acid	Haloacetic Acids (HAAs)	TG-ENV-WW-79 (GC-ECD)	2
Chloroacetic acid			2
Dibromoacetic acid			2
Dichloroacetic acid			2
Trichloroacetic acid			2
<b>Contaminants of Concern (COCs)</b>			
Methylene chloride	Halogenated Aliphatics	TG-ENV-WW-78 (Headspace GC-MS)	20
Carbon tetrachloride			0.5
1,1-dichloroethane			0.5
1,2-dichloroethane			0.5
1,1-dichloroethylene			0.5
1,2-dichloropropane			0.5
Tetrachloroethylene			0.5
1,1,1-trichloroethane			0.5
1,1,2-trichloroethane	Halogenated Aliphatics	TG-ENV-WW-78 (GC-MS)	0.5
Trichloroethylene			0.5
2-chlorophenol	Phenols & Haloethers	TG-ENV-WW-80 (GC-MS)	0.5
2,4-dichlorophenol			0.5
p-chloro-m-cresol			0.5
Pentachlorophenol			0.5
2,4,6-trichlorophenol			0.5
Bis(2-chloroethoxy) methane			0.5
Chlorobenzene	Chlorinated Hydrocarbons & Organochlorine Pesticides	TG-ENV-WW-78 (Headspace GC-MS)	0.5
1,4-dichlorobenzene			0.5
Hexachlorobenzene		USEPA 625	0.01
Hexachlorocyclopentadiene			2.5
Hexachloroethane			0.5
1,2,4-trichlorobenzene			0.5
Alpha-BHC			0.01
Beta-BHC			0.01
Gamma-BHC			0.01



# CMA Testing and Certification Laboratories

廠商會檢定中心

Report No.: AY0026486(4)

Term Contract for Provision of Sampling and Analyzing of Wastewater  
and Sludge Samples for Various Sewage Treatment Facilities and Marine Water Samples in Urban Area,  
Lantau and Outlying Islands to the Drainage Services Department

---

### 3. RESULTS AND OBSERVATIONS

#### Effluent Quality

- 3.1. The results of effluent quality monitoring conducted on the time period of 10:00am 26 Apr 2019 to 10:00am of 27 Apr 2019, whereas the laboratory testing and QC report are shown in **Appendix I-Report no. AY0026485(3)**.



# CMA Testing and Certification Laboratories

廠商會檢定中心

Report No.: AY0026486(4)

Term Contract for Provision of Sampling and Analyzing of Wastewater  
and Sludge Samples for Various Sewage Treatment Facilities and Marine Water Samples in Urban Area,  
Lantau and Outlying Islands to the Drainage Services Department

---

## Appendix I - Report for Laboratory Test(s)





# CMA Testing and Certification Laboratories

廠商會檢定中心

## TEST REPORT

Report No. : AY0026485(3) Date: 23 May 2019

Application No. : LY012826(8)

Applicant : SEWAGE TREATMENT DIVISION 2  
ELECTRICAL AND MECHANICAL BRANCH  
DRAINAGE SERVICES DEPARTMENT  
STONECUTTERS ISLAND SEWAGE TREATMENT WORKS.,  
NGONG SHUNG ROAD, NGONG SHUEN CHAU,  
KOWLOON, HONG KONG

Contract No. : DE/2018/02

Project Name : Term Contract for Provision of Sampling and Analyzing of  
Wastewater and Sludge Samples for Various Sewage Treatment  
Facilities and Marine Water Samples in Urban Area, Lantau and  
Outlying Islands to the Drainage Services Department

Sample Description : One (1) wastewater sample sampled by the staff of CMA Industrial  
Development Foundation Limited.  
Sample was refrigerated during delivery.

Sample ID : Refer to Sample ID on page 4.

Sampling Location : SCISTW- Disinfection Facilities

Sampling Date : 26 Apr 2019 to 27 Apr 2019.

Date Received : 27 Apr 2019.

Test Period : 27 Apr 2019 to 15 May 2019.

For and on behalf of  
CMA Industrial Development Foundation Limited

Authorized Signature : \_\_\_\_\_

  
Lau Yan Kin  
Senior Manager  
Environmental Division

Page 1 of 5



# CMA Testing and Certification Laboratories

廠商會檢定中心

## TEST REPORT

Report No. : AY0026485(3)

Date: 23 May 2019

Application No. : LY012826(8)

Test Requested :

1. Total Residual Chlorine
2. Bromoform
3. Bromodichloromethane
4. Chloroform
5. Dibromochloromethane
6. Bromoacetic acid
7. Chloroacetic acid
8. Dibromoacetic acid
9. Dichloroacetic acid
10. Trichloroacetic acid
11. Methylene chloride
12. Carbon tetrachloride
13. 1,1-dichloroethane
14. 1,2-dichloroethane
15. 1,1-dichloroethylene
16. 1,2-dichloropropane
17. Tetrachloroethylene
18. 1,1,1-trichloroethane
19. 1,1,2-trichloroethane
20. Trichloroethylene
21. 2-chlorophenol
22. 2,4-dichlorophenol
23. p-chloro-m-cresol
24. Pentachlorophenol
25. 2,4,6-trichlorophenol
26. Bis(2-chloroethoxy) methane
27. Chlorobenzene
28. 1,4-dichlorobenzene
29. Hexachlorobenzene
30. Hexachlorocyclopentadiene
31. Hexachloroethane
32. 1,2,4-trichlorobenzene
33. Alpha-BHC
34. Beta-BHC
35. Gamma-BHC



# CMA Testing and Certification Laboratories

廠商會檢定中心

## TEST REPORT

Report No. : AY0026485(3)

Date: 23 May 2019

Application No. : LY012826(8)

Test Method : 1. APHA 21ed Cl G  
2. TG-ENV-WW-78 (Headspace GC-MS)  
3. TG-ENV-WW-78 (Headspace GC-MS)  
4. TG-ENV-WW-78 (Headspace GC-MS)  
5. TG-ENV-WW-78 (Headspace GC-MS)  
6. TG-ENV-WW-79 (GC-ECD)  
7. TG-ENV-WW-79 (GC-ECD)  
8. TG-ENV-WW-79 (GC-ECD)  
9. TG-ENV-WW-79 (GC-ECD)  
10. TG-ENV-WW-79 (GC-ECD)  
11. TG-ENV-WW-78 (Headspace GC-MS)  
12. TG-ENV-WW-78 (Headspace GC-MS)  
13. TG-ENV-WW-78 (Headspace GC-MS)  
14. TG-ENV-WW-78 (Headspace GC-MS)  
15. TG-ENV-WW-78 (Headspace GC-MS)  
16. TG-ENV-WW-78 (Headspace GC-MS)  
17. TG-ENV-WW-78 (Headspace GC-MS)  
18. TG-ENV-WW-78 (Headspace GC-MS)  
19. TG-ENV-WW-78 (Headspace GC-MS)  
20. TG-ENV-WW-78 (Headspace GC-MS)  
21. TG-ENV-WW-80 (GC-MS)  
22. TG-ENV-WW-80 (GC-MS)  
23. TG-ENV-WW-80 (GC-MS)  
24. TG-ENV-WW-80 (GC-MS)  
25. TG-ENV-WW-80 (GC-MS)  
26. TG-ENV-WW-80 (GC-MS)  
27. TG-ENV-WW-78 (Headspace GC-MS)  
28. TG-ENV-WW-78 (Headspace GC-MS)  
29. USEPA 625  
30. USEPA 625  
31. USEPA 625  
32. USEPA 625  
33. USEPA 625  
34. USEPA 625  
35. USEPA 625

Test Result : Refer to results on page 4.



# CMA Testing and Certification Laboratories

廠商會檢定中心

## TEST REPORT

Report No. : AY0026485(3)

Date: 23 May 2019

Application No. : LY012826(8)

### Effluent Water Quality

Application No.:	LY012826
Sampling Date	26-Apr-19 to 27-Apr-19
Monitoring Location	Chamber 15A
<b>Parameter</b>	<b>Results (mg/L)</b>
Total Residual Chlorine	<0.01
<b>Parameter</b>	<b>Results (µg/L)</b>
Bromoform	1.0
Bromodichloromethane	0.6
Chloroform	8.7
Dibromochloromethane	<5
Bromoacetic acid	<2
Chloroacetic acid	<2
Dibromoacetic acid	<2
Dichloroacetic acid	7.3
Trichloroacetic acid	3.2
<b>Parameter</b>	<b>Results (µg/L)</b>
Methylene chloride	<20
Carbon tetrachloride	<0.5
1,1-dichloroethane	<0.5
1,2-dichloroethane	<0.5
1,1-dichloroethylene	<0.5
1,2-dichloropropane	<0.5
Tetrachloroethylene	1.3
1,1,1-trichloroethane	<0.5
1,1,2-trichloroethane	<0.5
Trichloroethylene	1.2
2-chlorophenol	<0.5
2,4-dichlorophenol	<0.5
p-chloro-m-cresol	<0.5
Pentachlorophenol	<0.5
2,4,6-trichlorophenol	<0.5
Bis(2-chloroethoxy) methane	<0.5
Chlorobenzene	<0.5
1,4-dichlorobenzene	<0.5
Hexachlorobenzene	<0.01
Hexachlorocyclopentadiene	<2.5
Hexachloroethane	<0.5
1,2,4-trichlorobenzene	<0.5
Alpha-BHC	<0.01
Beta-BHC	<0.01
Gamma-BHC	<0.01



# CMA Testing and Certification Laboratories

廠商會檢定中心

## TEST REPORT

Date: 23 May 2019

Report No. : AY0026485(3)

Application No. : LY012826(8)

### QC Report

Sampling Date : 26-Apr-19 to 27-Apr-19

Parameter	Method Blank (µg/L)	Acceptance Criteria (µg/L)	QC Recovery (%)	Acceptance Criteria (%)	Spike Recovery (%)	Acceptance Criteria (%)	Duplicate (RPD) (%)	Acceptance Criteria (%)
Bromoform	<0.02	<0.02	88	80-120	117	70-130	4	≤20
Bromodichloromethane	<0.02	<0.02	92	80-120	106	70-130	9	≤20
Chloroform	<0.02	<0.02	93	80-120	83	70-130	5	≤20
Dibromochloromethane	<1	<1	116	80-120	92	70-130	12	≤20
Bromoacetic acid	<0.4	<0.4	103	80-120	113	70-130	14	≤20
Chloroacetic acid	<0.4	<0.4	97	80-120	97	70-130	8	≤20
Dibromoacetic acid	<0.4	<0.4	84	80-120	102	70-130	13	≤20
Dichloroacetic acid	<0.4	<0.4	112	80-120	87	70-130	2	≤20
Trichloroacetic acid	<0.4	<0.4	84	80-120	91	70-130	17	≤20
Parameter	(µg/L)	(µg/L)	(%)	(%)	(%)	(%)	(%)	(%)
Methylene chloride	<4	<4	97	80-120	105	70-130	6	≤20
Carbon tetrachloride	<0.1	<0.1	112	80-120	94	70-130	3	≤20
1,1-dichloroethane	<0.1	<0.1	106	80-120	113	70-130	9	≤20
1,2-dichloroethane	<0.1	<0.1	109	80-120	87	70-130	11	≤20
1,1-dibromoethylene	<0.1	<0.1	96	80-120	73	70-130	4	≤20
1,2-dichloropropane	<0.1	<0.1	84	80-120	92	70-130	16	≤20
Tetrachloroethylene	<0.1	<0.1	105	80-120	109	70-130	10	≤20
1,1,1-trichloroethane	<0.1	<0.1	92	80-120	110	70-130	13	≤20
1,1,2-trichloroethane	<0.1	<0.1	112	80-120	96	70-130	9	≤20
Trichloroethylene	<0.1	<0.1	107	80-120	82	70-130	2	≤20
2-chlorophenol	<0.1	<0.1	93	80-120	121	70-130	8	≤20
2,4-dichlorophenol	<0.1	<0.1	86	80-120	108	70-130	7	≤20
p-chloro-m-cresol	<0.1	<0.1	82	80-120	117	70-130	14	≤20
Pentachlorophenol	<0.1	<0.1	115	80-120	121	70-130	10	≤20
2,4,6-trichlorophenol	<0.1	<0.1	98	80-120	105	70-130	5	≤20
Bis(2-chloroethoxy) methane	<0.1	<0.1	106	80-120	76	70-130	3	≤20
Chlorobenzene	<0.1	<0.1	113	80-120	109	70-130	9	≤20
1,4-dichlorobenzene	<0.1	<0.1	97	80-120	83	70-130	7	≤20
Hexachlorobenzene	<0.005	<0.005	85	80-120	103	70-130	13	≤20
Hexachlorocyclopentadiene	<0.5	<0.5	85	80-120	115	70-130	6	≤20
Hexachloroethane	<0.1	<0.1	113	80-120	95	70-130	8	≤20
1,2,4-trichlorobenzene	<0.1	<0.1	87	80-120	82	70-130	2	≤20
Alpha-BHC	<0.005	<0.005	116	80-120	99	70-130	7	≤20
Beta-BHC	<0.005	<0.005	104	80-120	113	70-130	15	≤20
Gamma-BHC	<0.005	<0.005	111	80-120	116	70-130	5	≤20

\*\*\*\*\* End of Report \*\*\*\*\*