



**CMA Testing  
and Certification  
Laboratories**

廠商會檢定中心

**Term Contract for Provision of Sampling and Analyzing of  
Wastewater and Sludge Samples for Various Sewage Treatment  
Facilities add Marine Water Samples in Urban Area, Lantau and  
Outlying Islands to the Drainage Service Department**

**Provision of Routine Marine Water Quality Monitoring Services**

**Report for the Month of Jul 2019**

Contract No. : DE/2018/02

Applicant : SEWAGE TREATMENT DIVISION 2  
ELECTRICAL AND MECHANICAL BRANCH  
DRAINAGE SERVICES DEPARTMENT

Address : STONECUTTERS ISLAND SEWAGE TREATMENT WORKS.,  
NGONG SHUNG ROAD, NGONG SHUEN CHAU,  
KOWLOON, HONG KONG


Application Number : LY024661(8)

Report Number : AY0045505(8)

Report Issued Date : 16 Aug 2019

For and on behalf of  
CMA Industrial Development Foundation Limited

Authorized Signature : \_\_\_\_\_

  
Lau Yan Kin  
Senior Manager  
Environmental Division



# CMA Testing and Certification Laboratories

廠商會檢定中心

Report No.: AY0045505(8)

Term Contract for Provision of Sampling and Analyzing of Wastewater and Sludge Samples for Various Sewage Treatment Facilities and Marine Water Samples in Urban Area, Lantau and Outlying Islands to the Drainage Services Department

---

## TABLE OF CONTENT

---

1. Introduction	2
2. Marine Water Quality Monitoring	3 – 5
3. Results and Observations	5
Appendix	
Appendix I – Location of Monitoring Stations	
Appendix II – Report for Laboratory Test(s)	



# CMA Testing and Certification Laboratories

廠商會檢定中心

Report No.: AY0045505(8)

Term Contract for Provision of Sampling and Analyzing of Wastewater and Sludge Samples for Various Sewage Treatment Facilities and Marine Water Samples in Urban Area, Lantau and Outlying Islands to the Drainage Services Department

## EXECUTIVE SUMMARY

1. This is the water quality monitoring report prepared by CMA Testing and Certification Laboratory (CMA Testing) for Contract No. DE/2018/02 ‘Term Contract for Provision of Sampling and analysing of Wastewater and Sludge Samples for Various Sewage Treatment Facilities and Marine Water Samples in Urban Area, Lantau and Outlying Islands to the Drainage Services Department (2018-2020)’. This report documented the results and findings of Operation Phase Environmental Monitoring works conducted for Routine Marine Water Quality Monitoring (rMWQM) of Project in Jul 2019.
2. In accordance with the Final EM&A Manual, environmental monitoring has been conducted in the reporting month with a Quarterly Basis for various parameters as summarized in **Table I**.

**Table I Summary Table for Environmental Monitoring Works Conducted in the Reporting Month**

Monitoring Parameters	Monitoring Date	Laboratory Testing Parameters
Marine Water Quality	26 Jul 2019	E.coli, Total Residual Chlorine (TRC), Chlorination by-products (CBPs) and Contaminants of Concern (COCs)



# CMA Testing and Certification Laboratories

廠商會檢定中心

Report No.: AY0045505(8)

Term Contract for Provision of Sampling and Analyzing of Wastewater and Sludge Samples for Various Sewage Treatment Facilities and Marine Water Samples in Urban Area, Lantau and Outlying Islands to the Drainage Services Department

---

## 1. INTRODUCTION

- 1.1. CMA Testing was commissioned by Drainage Services Department (DSD) to undertake the operation phase environmental monitoring for Advance Disinfection Facilities (ADF) at Stonecutters Island Sewage Treatment Works (SCISTW) (thereafter called the “the Services”).
- 1.2. The operation phase monitoring, which include effluent quality monitoring, marine water quality monitoring and emergency discharge monitoring, is to monitor the effluent and marine water quality impact of ADF during its operation phase.
- 1.3. This is the water quality monitoring report prepared by CMA Testing that documented the results and findings of Operation Phase Water Quality Monitoring works conducted for Routine Marine Water Quality Monitoring (rMWQM) of Project on 26 Jul 2019.



# CMA Testing and Certification Laboratories

廠商會檢定中心

Report No.: AY0045505(8)

Term Contract for Provision of Sampling and Analyzing of Wastewater and Sludge Samples for Various Sewage Treatment Facilities and Marine Water Samples in Urban Area, Lantau and Outlying Islands to the Drainage Services Department

## 2. MARINE WATER QUALITY MONITORING

### Monitoring Requirements

- 2.1. Monitoring was taken at three water depths, namely, 1m below water surface, mid-depth and 1m above sea bed, except where the water depth is less than 6m, in which case the mid-depth station may be omitted. If the water depth be less than 3m, only the mid-depth station will be monitored.
- 2.2. Six samples (replicates) at each monitoring stations were collected by collecting the same amount of water sample at each depth.
- 2.3. One grab sample was collected at each water depth for E.coli analysis.

### Monitoring Locations

- 2.4. Six monitoring stations were designated for the marine water quality monitoring programme. The locations are summarized in Table 2.1 and shown on **Figure 2**.

**Table 2.1 Proposed Marine Water Quality Monitoring Stations**

Station	Description	Coordinates	
		Easting	Northing
1	Edge of Mixing Zone (northwest of effluent diffuser)	829762.00	819604.47
2	Edge of ZID (northwest of effluent diffuser)	830117.99	819251.93
3	Edge of ZID (southeast of effluent diffuser)	830186.21	819184.37
4	Edge of Mixing Zone (southeast of effluent diffuser)	830525.00	818848.87
SM6	Control Station	826179.81	805902.89
SM12	Control Station	819524.19	808420.40

### Monitoring Schedule

- 2.5. The marine water quality monitoring was conducted coincide with effluent quality monitoring on 26 Jul 2019.

### Monitoring Equipment

- 2.6. The equipment used in the marine water quality monitoring in the reporting month is summarized in Table 2.2. Copies of calibration certificates are shown in **Appendix II-Report no. AY0045504(7)**.

**Table 2.2 Marine Water Quality Monitoring Equipment**

Equipment	Model and Make	Qty
Water Sampler	Kahlsico Water Sampler	1
Water Depth Detector	Seafarer 700	1
Positioning System	Global Positioning System (GPS)	1
Multi-parameter Water Quality System	Model YSI 6920 V2	1



# CMA Testing and Certification Laboratories

廠商會檢定中心

Report No.: AY0045505(8)

Term Contract for Provision of Sampling and Analyzing of Wastewater and Sludge Samples for Various Sewage Treatment Facilities and Marine Water Samples in Urban Area, Lantau and Outlying Islands to the Drainage Services Department

## Monitoring Parameters and Frequency

- 2.7. Marine Water sampling on E.coli, Total Residual Chlorine (TRC), Chlorination By-Products (CBPs) and the Contaminants of Concern (COCs) shall be performed quarterly throughout the contract period.
- 2.8. The list of parameters to be analysed as well as the corresponding analytical methods and detection limit are listed in Table 2.3

**Table 2.3 Analytical Methods for Laboratory Analysis for Marine Water Samples**

Parameters		Analytical Method	Limit of Reporting (µg/L)
<b>TRC and Potential CBPs</b>			
Total residual Chlorine		APHA 21ed 4500 Cl G	10
Bromoform	Tri-halomethanes (THMs)	TG-ENV-WW-78 (Headspace GC-MS)	0.1
Bromodichloromethane			0.1
Chloroform			0.1
Dibromochloromethane			5
Bromoacetic acid	Haloacetic Acids (HAAs)	TG-ENV-WW-79 (GC-ECD)	2
Chloroacetic acid			2
Dibromoacetic acid			2
Dichloroacetic acid			2
Trichloroacetic acid			2
<b>Bacteria</b>			
E.coli		Environmental Monitoring Laboratory Test Method Manual TM09/EC/10/097 Issue 3, Environmental Protection Department, HK.	1 cfu/100ml
<b>Contaminants of Concern (COCs)</b>			
Methylene chloride	Halogenated Aliphatics	TG-ENV-WW-78 (Headspace GC-MS)	20
Carbon tetrachloride			0.5
1,1-dichloroethane			0.5
1,2-dichloroethane			0.5
1,1-dichloroethylene			0.5
1,2-dichloropropane			0.5
Tetrachloroethylene			0.5
1,1,1-trichloroethane	Halogenated Aliphatics		0.5
1,1,2-trichloroethane			0.5
Trichloroethylene			0.5
2-chlorophenol	Phenols & Haloethers	TG-ENV-WW-80 (GC-MS)	0.5
2,4-dichlorophenol			0.5
p-chloro-m-cresol			0.5



# CMA Testing and Certification Laboratories

廠商會檢定中心

Report No.: AY0045505(8)

Term Contract for Provision of Sampling and Analyzing of Wastewater and Sludge Samples for Various Sewage Treatment Facilities and Marine Water Samples in Urban Area, Lantau and Outlying Islands to the Drainage Services Department

Pentachlorophenol			0.5
2,4,6-trichlorophenol			0.5
Bis(2-chloroethoxy) methane			0.5
Chlorobenzene		TG-ENV-WW-78	0.5
1,4-dichlorobenzene		(Headspace GC-MS)	0.5
Hexachlorobenzene	Chlorinated Hydrocarbons & Organochlorine Pesticides	USEPA 625	0.01
Hexachlorocyclopentadiene			2.5
Hexachloroethane			0.5
1,2,4-trichlorobenzene			0.5
Alpha-BHC			0.01
Beta-BHC			0.01
Gamma-BHC			0.01

### 3. RESULTS AND OBSERVATIONS

#### Weather and Sea Condition

- 3.1. The weather condition was Fine while the sea condition was moderate during the sampling period 26 Jul 2019 in the reporting month.

#### Marine Water Quality

- 3.2. The in-situ measurement results including dissolved oxygen, turbidity, salinity, pH and temperature of the marine water monitoring. Also, the results of marine water quality monitoring conducted on 26 Apr 2019 and QC report are shown in **Appendix II – Report no. AY0045504(7)**.



**CMA Testing  
and Certification  
Laboratories**

廠商會檢定中心

Report No.: AY0045505(8)

Term Contract for Provision of Sampling and Analyzing of Wastewater and Sludge Samples for Various Sewage Treatment Facilities and Marine Water Samples in Urban Area, Lantau and Outlying Islands to the Drainage Services Department

---

## Appendix I - Location of Monitoring Stations






# CMA Testing and Certification Laboratories

廠商會檢定中心

Report No.: AY0045505(8)

Term Contract for Provision of Sampling and Analyzing of Wastewater and Sludge Samples for Various Sewage Treatment Facilities and Marine Water Samples in Urban Area, Lantau and Outlying Islands to the Drainage Services Department





**CMA Testing  
and Certification  
Laboratories**

廠商會檢定中心

Report No.: AY0045505(8)

Term Contract for Provision of Sampling and Analyzing of Wastewater and Sludge Samples for Various Sewage Treatment Facilities and Marine Water Samples in Urban Area, Lantau and Outlying Islands to the Drainage Services Department

---

## Appendix II - Report for Laboratory Test(s)



# CMA Testing and Certification Laboratories

廠商會檢定中心

## TEST REPORT

Report No. : AY0045504(7) Date: 16 Aug 2019

Application No. : LY024661(8)

Applicant : SEWAGE TREATMENT DIVISION 2  
ELECTRICAL AND MECHANICAL BRANCH  
DRAINAGE SERVICES DEPARTMENT  
STONECUTTERS ISLAND SEWAGE TREATMENT WORKS.,  
NGONG SHUNG ROAD, NGONG SHUEN CHAU,  
KOWLOON, HONG KONG

Contract No. : DE/2018/02

Project Name : Term Contract for Provision of Sampling and Analyzing of Wastewater and Sludge Samples for Various Sewage Treatment Facilities and Marine Water Samples in Urban Area, Lantau and Outlying Islands to the Drainage Services Department

Sample Description : Eighteen (18) marine water samples sampled by the staff of CMA Industrial Development Foundation Limited.  
Samples were refrigerated during delivery.

Sample ID : Refer to Sample ID on page 4 to 11.

Station	Description	Coordinates	
		Easting	Northing
1	Edge of Mixing Zone (northwest of effluent diffuser)	829762.00	819604.47
2	Edge of ZID (northwest of effluent diffuser)	830117.99	819251.93
3	Edge of ZID (southeast of effluent diffuser)	830186.21	819184.37
4	Edge of Mixing Zone (southeast of effluent diffuser)	830525.00	818848.87
SM6	Control Station	826179.81	805902.89
SM12	Control Station	819524.19	808420.40

For and on behalf of  
CMA Industrial Development Foundation Limited

Authorized Signature : \_\_\_\_\_

Lau Yan Kin  
Senior Manager  
Environmental Division

Page 1 of 16



# CMA Testing and Certification Laboratories

廠商會檢定中心

## TEST REPORT

Report No. : AY0045504(7) Date: 16 Aug 2019

Application No. : LY024661(8)

Sampling Date : 26 Jul 2019.

Date Received : 26 Jul 2019.

Test Period : 26 Jul 2019 to 15 Aug 2019.

Test Requested :

1. Temperature (on-site measurement)
2. pH (on-site measurement)
3. Salinity (on-site measurement)
4. Dissolved Oxygen (DO) (mg/L) (on-site measurement)
5. Dissolved Oxygen (DOS) (% saturation) (on-site measurement)
6. Turbidity (on-site measurement)
7. Total Residual Chlorine (on-site measurement)
8. E. coli count
9. Bromoform
10. Bromodichloromethane
11. Chloroform
12. Dibromochloromethane
13. Bromoacetic acid
14. Chloroacetic acid
15. Dibromoacetic acid
16. Dichloroacetic acid
17. Trichloroacetic acid
18. Methylene chloride
19. Carbon tetrachloride
20. 1,1-dichloroethane
21. 1,2-dichloroethane
22. 1,1-dichloroethylene
23. 1,2-dichloropropane
24. Tetrachloroethylene
25. 1,1,1-trichloroethane
26. 1,1,2-trichloroethane
27. Trichloroethylene
28. 2-chlorophenol
29. 2,4-dichlorophenol
30. p-chloro-m-cresol
31. Pentachlorophenol
32. 2,4,6-trichlorophenol
33. Bis(2-chloroethoxy) methane
34. Chlorobenzene
35. 1,4-dichlorobenzene
36. Hexachlorobenzene
37. Hexachlorocyclopentadiene
38. Hexachloroethane
39. 1,2,4-trichlorobenzene
40. Alpha-BHC
41. Beta-BHC
42. Gamma-BHC

Page 2 of 16



# CMA Testing and Certification Laboratories

廠商會檢定中心

## TEST REPORT

Report No. : AY0045504(7)

Date: 16 Aug 2019

Application No. : LY024661(8)

Test Method : 1-5. In house method (By multimeter)  
6. APHA 2130B  
7. APHA 21ed 4500 Cl G  
8. Environmental Monitoring Laboratory Test Method Manual  
TM09/EC/10/097 Issue 3, Environmental Protection Department,  
HK.  
9. TG-ENV-WW-78 (Headspace GC-MS)  
10. TG-ENV-WW-78 (Headspace GC-MS)  
11. TG-ENV-WW-78 (Headspace GC-MS)  
12. TG-ENV-WW-78 (Headspace GC-MS)  
13. TG-ENV-WW-79 (GC-ECD)  
14. TG-ENV-WW-79 (GC-ECD)  
15. TG-ENV-WW-79 (GC-ECD)  
16. TG-ENV-WW-79 (GC-ECD)  
17. TG-ENV-WW-79 (GC-ECD)  
18. TG-ENV-WW-78 (Headspace GC-MS)  
19. TG-ENV-WW-78 (Headspace GC-MS)  
20. TG-ENV-WW-78 (Headspace GC-MS)  
21. TG-ENV-WW-78 (Headspace GC-MS)  
22. TG-ENV-WW-78 (Headspace GC-MS)  
23. TG-ENV-WW-78 (Headspace GC-MS)  
24. TG-ENV-WW-78 (Headspace GC-MS)  
25. TG-ENV-WW-78 (Headspace GC-MS)  
26. TG-ENV-WW-78 (Headspace GC-MS)  
27. TG-ENV-WW-78 (Headspace GC-MS)  
28. TG-ENV-WW-80 (GC-MS)  
29. TG-ENV-WW-80 (GC-MS)  
30. TG-ENV-WW-80 (GC-MS)  
31. TG-ENV-WW-80 (GC-MS)  
32. TG-ENV-WW-80 (GC-MS)  
33. TG-ENV-WW-80 (GC-MS)  
34. TG-ENV-WW-78 (Headspace GC-MS)  
35. TG-ENV-WW-78 (Headspace GC-MS)  
36. USEPA 625  
37. USEPA 625  
38. USEPA 625  
39. USEPA 625  
40. USEPA 625  
41. USEPA 625  
42. USEPA 625

Test Result : Refer to results on page 4 to 11.



# CMA Testing and Certification Laboratories

廠商會檢定中心

## TEST REPORT

Date: 16 Aug 2019

Report No. : AY0045504(7)

Application No. : LY024661(8)

Marine Water Quality

Sampling Date : 26-Jul-2019

Monitoring Location	Time	Water Depth (m)	Sampling Depth (m)	E.coli (CFU/100mL)	Temperature (°C)		Salinity (ppt)		pH		DO (mg/L)		DOS (%)		Turbidity (NTU)		TRC (mg/L)	
					1	2	1	2	1	2	1	2	1	2	1	2	1	2
1	15:29	9.7	1.0	16	29.2	29.2	23.8	23.8	8.6	8.6	10.2	10.2	152.1	152.1	2.9	2.9	<0.01	<0.01
			4.9	200	27.0	27.0	29.0	29.0	8.1	8.1	8.8	8.8	130.7	130.7	3.3	3.3	0.03	0.03
			8.7	280	25.2	25.2	31.0	31.0	7.8	7.8	5.4	5.4	78.3	78.3	3.9	3.9	0.02	0.02
2	15:20	10.3	1.0	8	29.0	29.0	24.1	24.1	8.6	8.6	10.0	10.0	148.3	148.3	3.1	3.1	<0.01	<0.01
			5.2	26	26.5	26.5	29.6	29.6	8.0	8.0	7.7	7.7	112.6	112.6	3.5	3.5	0.03	0.03
			9.3	65	24.9	24.9	32.1	32.1	7.9	7.9	4.5	4.5	65.6	65.6	3.9	3.9	0.01	0.01
3	15:14	10.1	1.0	37	29.1	29.1	25.3	25.3	8.6	8.6	10.3	10.3	153.6	153.6	3.3	3.3	0.02	0.02
			5.1	280	26.0	26.0	30.2	30.2	8.0	8.0	7.1	7.1	104.0	104.0	3.6	3.6	0.03	0.03
			9.1	540	25.1	25.1	31.3	31.3	7.8	7.8	5.2	5.2	75.2	75.2	3.9	3.9	0.02	0.02
4	15:05	9.6	1.0	52	25.9	25.9	30.0	30.0	8.0	8.0	8.0	8.0	116.0	116.0	3.1	3.1	0.01	0.01
			4.8	260	25.3	25.3	31.2	31.2	7.9	7.9	4.3	4.3	61.9	61.9	3.8	3.8	0.02	0.02
			8.6	280	25.2	25.2	31.3	31.3	7.9	7.9	3.7	3.7	53.1	53.1	4.2	4.2	<0.01	<0.01
SM6	13:09	14.8	1.0	10	26.9	26.9	27.4	27.4	8.5	8.5	6.9	6.9	100.1	100.1	2.3	2.3	<0.01	<0.01
			7.4	32	26.4	26.4	28.3	28.3	8.5	8.5	5.8	5.8	85.0	85.0	3.1	3.1	0.01	0.01
			13.8	46	24.3	24.3	33.3	33.3	8.1	8.1	1.1	1.1	16.4	16.4	3.3	3.3	0.02	0.02
SM12	12:26	9.0	1.0	9	28.3	28.3	25.5	25.5	8.7	8.7	9.6	9.6	141.4	141.4	2.5	2.5	0.01	0.01
			4.5	46	25.4	25.4	30.4	30.4	8.1	8.1	4.7	4.7	67.3	67.3	3.6	3.6	0.01	0.01
			8.0	26	25.2	25.2	31.2	31.2	8.1	8.1	1.4	1.4	20.7	20.7	6.0	6.0	0.02	0.02



# CMA Testing and Certification Laboratories

廠商會檢定中心

## TEST REPORT

Date: 16 Aug 2019

Report No. : AY0045504(7)

Application No. : LY024661(8)

Marine Water Quality

Sampling Date : 26-Jul-2019

Monitoring Location	Time	Water Depth (m)	Sampling Depth (m)	Bromoform (µg/L)	Bromodichloromethane (µg/L)	Chloroform (µg/L)		Dibromochloromethane (µg/L)	Bromoacetic acid (µg/L)	Chloroacetic acid (µg/L)		Dibromoacetic acid (µg/L)
						<0.1	<0.1			<2	<2	
1	15:29	9.7	1.0	<0.1	<0.1	<0.1	<0.1	<5	<2	<2	<2	<2
			4.9	<0.1	<0.1	<0.1	<0.1	<5	<2	<2	<2	<2
			8.7	<0.1	<0.1	<0.1	<0.1	<5	<2	<2	<2	<2
2	15:20	10.3	1.0	0.1	<0.1	<0.1	<0.1	<5	<2	<2	<2	<2
			5.2	<0.1	<0.1	<0.1	<0.1	<5	<2	<2	<2	<2
			9.3	<0.1	<0.1	<0.1	<0.1	<5	<2	<2	<2	<2
3	15:14	10.1	1.0	0.1	<0.1	<0.1	<0.1	<5	<2	<2	<2	<2
			5.1	0.1	<0.1	<0.1	<0.1	<5	<2	<2	<2	<2
			9.1	<0.1	<0.1	<0.1	<0.1	<5	<2	<2	<2	<2
4	15:05	9.6	1.0	<0.1	<0.1	<0.1	<0.1	<5	<2	<2	<2	<2
			4.8	<0.1	<0.1	<0.1	<0.1	<5	<2	<2	<2	<2
			8.6	<0.1	<0.1	<0.1	<0.1	<5	<2	<2	<2	<2
SM6	13:09	14.8	1.0	0.1	<0.1	<0.1	<0.1	<5	<2	<2	<2	<2
			7.4	<0.1	<0.1	<0.1	<0.1	<5	<2	<2	<2	<2
			13.8	0.1	<0.1	<0.1	<0.1	<5	<2	<2	<2	<2
SM12	12:26	9.0	1.0	<0.1	<0.1	<0.1	<0.1	<5	<2	<2	<2	<2
			4.5	<0.1	<0.1	<0.1	<0.1	<5	<2	<2	<2	<2
			8.0	0.1	<0.1	<0.1	<0.1	<5	<2	<2	<2	<2
			LRV	<0.1	<0.1	<0.1	<0.1	<5	<2	<2	<2	



# CMA Testing and Certification Laboratories

廠商會檢定中心

## TEST REPORT

Date: 16 Aug 2019

Report No. : AY0045504(7)

Application No. : LY024661(8)

Marine Water Quality

Sampling Date 26-Jul-2019

Monitoring Location	Time	Water Depth (m)	Sampling Depth (m)	Dichloroacetic acid (µg/L)	Trichloroacetic acid (µg/L)
1	15:29	9.7	1.0	<2	<2
			4.9	<2	<2
			8.7	<2	<2
2	15:20	10.3	1.0	<2	<2
			5.2	<2	<2
			9.3	<2	<2
3	15:14	10.1	1.0	<2	<2
			5.1	<2	<2
			9.1	<2	<2
4	15:05	9.6	1.0	<2	<2
			4.8	<2	<2
			8.6	<2	<2
SM6	13:09	14.8	1.0	<2	<2
			7.4	<2	<2
			13.8	<2	<2
SM12	12:26	9.0	1.0	<2	<2
			4.5	<2	<2
			8.0	<2	<2
			LRV	<2	<2

Page 6 of 16





# CMA Testing and Certification Laboratories

廠商會檢定中心

## TEST REPORT

Date: 16 Aug 2019

Report No. : AY0045504(7)

Application No. : LY024661(8)

Marine Water Quality

Sampling Date : 26-Jul-2019

Monitoring Location	Time	Water Depth (m)	Sampling Depth (m)	Methylene chloride (µg/L)	Carbon tetrachloride (µg/L)	1,1-dibromoethane (µg/L)	1,2-dichloroethane (µg/L)	1,1-dibromoethene (µg/L)	1,2-dichloropropane (µg/L)	Tetrahydroethene (µg/L)
1	15:29	9.7	1.0	<20	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
			4.9	<20	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
			8.7	<20	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
2	15:20	10.3	1.0	<20	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
			5.2	<20	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
			9.3	<20	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
3	15:14	10.1	1.0	<20	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
			5.1	<20	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
			9.1	<20	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
4	15:05	9.6	1.0	<20	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
			4.8	<20	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
			8.6	<20	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
SM6	13:09	14.8	1.0	<20	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
			7.4	<20	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
			13.8	<20	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
SM12	12:26	9.0	1.0	<20	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
			4.5	<20	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
			8.0	<20	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
			LRV	<20	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5



# CMA Testing and Certification Laboratories

廠商會檢定中心

## TEST REPORT

Date: 16 Aug 2019

Report No. : AY0045504(7)

Application No. : LY024661(8)

### Marine Water Quality

Sampling Date 26-Jul-2019

Monitoring Location	Time	Water Depth (m)	Sampling Depth (m)	1,1,1-trichloroethane (µg/L)	1,1,2-trichloroethane (µg/L)	Trichloroethylene (µg/L)	2-chlorophenol (µg/L)	2,4-dichlorophenol (µg/L)	p-chloro-m-cresol (µg/L)	Pentachlorophenol (µg/L)
1	15:29	9.7	1.0	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
			4.9	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
			8.7	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
2	15:20	10.3	1.0	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
			5.2	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
			9.3	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
3	15:14	10.1	1.0	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
			5.1	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
			9.1	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
4	15:05	9.6	1.0	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
			4.8	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
			8.6	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
SM6	13:09	14.8	1.0	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
			7.4	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
			13.8	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
SM12	12:26	9.0	1.0	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
			4.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
			8.0	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
			LRV	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5



# CMA Testing and Certification Laboratories

廠商會檢定中心

## TEST REPORT

Date: 16 Aug 2019

Report No. : AY0045504(7)

Application No. : LY024661(8)

### Marine Water Quality

Sampling Date 26-Jul-2019

Monitoring Location	Time	Water Depth (m)	Sampling Depth (m)	2,4,6-trichlorophenol (µg/L)	Bis(2-chloroethoxy) methane (µg/L)	Chlorobenzene (µg/L)	1,4-dichlorobenzene (µg/L)	Hexachlorobenzene (µg/L)	Hexachlorocyclopentadiene (µg/L)	Hexachloroethane (µg/L)
1	15:29	9.7	1.0	<0.5	<0.5	<0.5	<0.5	<0.01	<2.5	<0.5
			4.9	<0.5	<0.5	<0.5	<0.01	<2.5	<0.5	
			8.7	<0.5	<0.5	<0.5	<0.01	<2.5	<0.5	
2	15:20	10.3	1.0	<0.5	<0.5	<0.5	<0.5	<0.01	<2.5	<0.5
			5.2	<0.5	<0.5	<0.5	<0.01	<2.5	<0.5	
			9.3	<0.5	<0.5	<0.5	<0.01	<2.5	<0.5	
3	15:14	10.1	1.0	<0.5	<0.5	<0.5	<0.5	<0.01	<2.5	<0.5
			5.1	<0.5	<0.5	<0.5	<0.01	<2.5	<0.5	
			9.1	<0.5	<0.5	<0.5	<0.01	<2.5	<0.5	
4	15:05	9.6	1.0	<0.5	<0.5	<0.5	<0.5	<0.01	<2.5	<0.5
			4.8	<0.5	<0.5	<0.5	<0.01	<2.5	<0.5	
			8.6	<0.5	<0.5	<0.5	<0.01	<2.5	<0.5	
SM6	13:09	14.8	1.0	<0.5	<0.5	<0.5	<0.5	<0.01	<2.5	<0.5
			7.4	<0.5	<0.5	<0.5	<0.01	<2.5	<0.5	
			13.8	<0.5	<0.5	<0.5	<0.01	<2.5	<0.5	
SM12	12:26	9.0	1.0	<0.5	<0.5	<0.5	<0.5	<0.01	<2.5	<0.5
			4.5	<0.5	<0.5	<0.5	<0.01	<2.5	<0.5	
			8.0	<0.5	<0.5	<0.5	<0.01	<2.5	<0.5	
			LRV	<0.5	<0.5	<0.5	<0.5	<0.01	<2.5	<0.5



# CMA Testing and Certification Laboratories

廠商會檢定中心

## TEST REPORT

Date: 16 Aug 2019

Report No. : AY0045504(7)

Application No. : LY024661(8)

Marine Water Quality

Sampling Date : 26-Jul-2019

Monitoring Location	Time	Water Depth (m)	Sampling Depth (m)	1,2,4-trichlorobenzene (µg/L)	Alpha-BHC (µg/L)	Beta-BHC (µg/L)	Gamma-BHC (µg/L)
1	15:29	9.7	1.0	<0.5	<0.01	<0.01	<0.01
			4.9	<0.5	<0.01	<0.01	<0.01
			8.7	<0.5	<0.01	<0.01	<0.01
2	15:20	10.3	1.0	<0.5	<0.01	<0.01	<0.01
			5.2	<0.5	<0.01	<0.01	<0.01
			9.3	<0.5	<0.01	<0.01	<0.01
3	15:14	10.1	1.0	<0.5	<0.01	<0.01	<0.01
			5.1	<0.5	<0.01	<0.01	<0.01
			9.1	<0.5	<0.01	<0.01	<0.01
4	15:05	9.6	1.0	<0.5	<0.01	<0.01	<0.01
			4.8	<0.5	<0.01	<0.01	<0.01
			8.6	<0.5	<0.01	<0.01	<0.01
SM6	13:09	14.8	1.0	<0.5	<0.01	<0.01	<0.01
			7.4	<0.5	<0.01	<0.01	<0.01
			13.8	<0.5	<0.01	<0.01	<0.01
SM12	12:26	9.0	1.0	<0.5	<0.01	<0.01	<0.01
			4.5	<0.5	<0.01	<0.01	<0.01
			8.0	<0.5	<0.01	<0.01	<0.01
			LRV	<0.5	<0.01	<0.01	<0.01



# CMA Testing and Certification Laboratories

廠商會檢定中心

## TEST REPORT

Date: 16 Aug 2019

Report No. : AY0045504(7)

Application No. : LY024661(8)

### QC Report

Sampling Date 26-Jul-2019

Parameter	Method Blank (µg/L)	Acceptance Criteria (µg/L)	QC Recovery (%)	Acceptance Criteria (%)	Spike Recovery (%)	Acceptance Criteria (%)	Duplicate (RPD) (%)	Acceptance Criteria (%)
Bromoform	<0.02	<0.02	113	80-120	94	70-130	4	≤20
Bromodichloromethane	<0.02	<0.02	106	80-120	108	70-130	3	≤20
Chloroform	<0.02	<0.02	87	80-120	103	70-130	9	≤20
Dibromochloromethane	<1	<1	104	80-120	112	70-130	15	≤20
Bromoacetic acid	<0.4	<0.4	95	80-120	91	70-130	3	≤20
Chloroacetic acid	<0.4	<0.4	104	80-120	104	70-130	12	≤20
Dibromoacetic acid	<0.4	<0.4	102	80-120	113	70-130	11	≤20
Dichloroacetic acid	<0.4	<0.4	92	80-120	85	70-130	7	≤20
Trichloroacetic acid	<0.4	<0.4	98	80-120	107	70-130	4	≤20
Parameter	(µg/L)	(µg/L)	(%)	(%)	(%)	(%)	(%)	(%)
Methylene chloride	<4	<4	102	80-120	117	70-130	6	≤20
Carbon tetrachloride	<0.1	<0.1	97	80-120	96	70-130	10	≤20
1,1-dichloroethane	<0.1	<0.1	95	80-120	105	70-130	3	≤20
1,2-dichloroethane	<0.1	<0.1	84	80-120	102	70-130	14	≤20
1,1-dichloroethylene	<0.1	<0.1	94	80-120	94	70-130	9	≤20
1,2-dichloropropane	<0.1	<0.1	107	80-120	95	70-130	15	≤20
Tetrachloroethylene	<0.1	<0.1	112	80-120	93	70-130	7	≤20
1,1,1-trichloroethane	<0.1	<0.1	106	80-120	88	70-130	12	≤20
1,1,2-trichloroethane	<0.1	<0.1	83	80-120	114	70-130	4	≤20
Trichloroethylene	<0.1	<0.1	91	80-120	97	70-130	8	≤20
2-chlorophenol	<0.1	<0.1	82	80-120	107	70-130	5	≤20
2,4-dichlorophenol	<0.1	<0.1	106	80-120	87	70-130	5	≤20
p-chloro-m-cresol	<0.1	<0.1	102	80-120	109	70-130	7	≤20
Pentachlorophenol	<0.1	<0.1	105	80-120	82	70-130	11	≤20
2,4,6-trichlorophenol	<0.1	<0.1	105	80-120	89	70-130	8	≤20
Bis(2-chloroethoxy) methane	<0.1	<0.1	87	80-120	104	70-130	4	≤20
Chlorobenzene	<0.1	<0.1	92	80-120	92	70-130	9	≤20
1,4-dichlorobenzene	<0.1	<0.1	115	80-120	94	70-130	6	≤20
Hexachlorobenzene	<0.005	<0.005	86	80-120	106	70-130	7	≤20
Hexachlorocyclopentadiene	<0.5	<0.5	114	80-120	94	70-130	4	≤20
Hexachloroethane	<0.1	<0.1	97	80-120	82	70-130	11	≤20
1,2,4-trichlorobenzene	<0.1	<0.1	94	80-120	116	70-130	6	≤20
Alpha-BHC	<0.005	<0.005	86	80-120	113	70-130	8	≤20
Beta-BHC	<0.005	<0.005	106	80-120	104	70-130	6	≤20
Gamma-BHC	<0.005	<0.005	95	80-120	97	70-130	7	≤20



# CMA Testing and Certification Laboratories

廠商會檢定中心

## TEST REPORT

Report No. : AY0045504(7)

Date: 16 Aug 2019

Application No. : LY024661(8)

Calibration Certificate



## Calibration Certificate

**Certificate No.: CC0101907**

### 1. Description

Calibration item :	a) pH at 25°C b) Temperature c) Dissolve Oxygen d) Conductivity at 25°C e) Salinity f) Oxidation-Reduction Potential (ORP)
Equipment description :	Multiparaters Instrument
Manufacturer :	YSI
Type / Model No. :	Professional Plus
Serial No. :	Meter: 11J100821
Assigned equipment no. :	N/A
Adjustment :	N/A
Remark :	Received with good condition

### 2. Customer information

Customer :	CMA Testing and Certification Laboratories
Address :	Room 1302, Yan Hing Centre, 9-13 Wong Chuk Yeung Street, Fotan, Shatin, NT, Hong Kong
Date of receipt :	8 July 2019

### 3. Date of performance of the calibration

Date of calibration :	10 July 2019
Next Calibration date :	10 October 2019



Authorized Signatory

Warren Yeung

Company Chop:

Certificate issue date: 12 July 2019

- The certificate shall not reproduced except in full without the written approval of CAL LAB LTD
- The Certificate is issued subject to the latest Term and Condition, available assessable at our web site

Page 1 of 3  
cc0101907

Cal Lab Limited

Address: Room 2103, Technology Plaza, 29-35 Sha Tsui Road, Tsuen Wan, NT, Hong Kong  
Tel : (852)25680106 Fax(852)30116194 Email: info@callab.com.hk Website:callab.com.hk



# CMA Testing and Certification Laboratories

廠商會檢定中心

## TEST REPORT

Report No. : AY0045504(7)

Date: 16 Aug 2019

Application No. : LY024661(8)



CALIBRATION

### 4. Result of Calibration

#### a) Temperature

Reference reading (°C)	Display Reading (°C)	Error of indication (°C)
15.05	15.4	0.4
25.11	25.3	0.2
34.92	34.6	-0.3

#### b) Dissolved Oxygen

Reference reading (mg/L)	Display Reading (mg/L)	Error of indication
0.00	0.00	0.00
3.92	4.05	0.13
7.94	8.12	0.18

#### c) Conductivity at 25°C

Reference reading (uS/cm)	Display Reading (uS/cm)	Error of indication (%)
145.3	150.7	3.7
1433	1460	1.9
13066	13291	1.7
59127	58216	-1.5
1114644	1098662	-1.4

#### d) Salinity

Reference reading (ppt)	Display Reading (ppt)	Error of indication (%)
10	9.93	-0.7
20	19.87	-0.6
30	29.92	-0.3

#### e) Oxidation-Reduction Potential (ORP)

Reference reading (mV)	Display Reading (mV)	Error of indication (mV)
+231	+229	2

- The certificate shall not be reproduced except in full without the written approval of CAL LAB LTD
- The Certificate is issued subject to the latest Term and Condition, available assessable at our web site

Page 2 of 3  
cc0101907

Cal Lab Limited  
Address: Room 2103, Technology Plaza, 29-35 Sha Tsui Road, Tsuen Wan, NT, Hong Kong  
Tel: (852) 25680106 Fax: (852) 30116194 Email: info@callab.com.hk Website: callab.com.hk



# CMA Testing and Certification Laboratories

廠商會檢定中心

## TEST REPORT

Report No. : AY0045504(7)

Date: 16 Aug 2019

Application No. : LY024661(8)



CALIBRATION

f) pH at 25°C

Reference reading	Display Reading	Error of indication
4.00	3.98	-0.02
6.86	6.82	-0.04
9.18	9.21	0.03
10.01	10.04	0.03

### 5. Reference method for calibration

pH at 25°C	APHA 21e 4500-H B
Dissolved Oxygen	APHA 21e 4500-O G
Conductivity at 25°C	APHA 21e 2510 B
Temperature	JJG 130-2011
Salinity	APHA 21e 2520 B
Oxidation-Reduction Potential (ORP)	APHA 21e 2580 B

### 6. Environment condition of calibration

Temperature ; °C	18 – 25 °C
Relative humidity ; %RH	< 75 %RH

\*\*\* End of Certificate \*\*\*

1. The certificate shall not reproduced except in full without the written approval of CAL LAB LTD
2. The Certificate is issued subject to the latest Term and Condition, available assessable at our web site

Page 3 of 3  
cc0101907

Cal Lab Limited  
Address: Room 2103, Technology Plaza, 29-35 Sha Tsui Road, Tsuen Wan, NT, Hong Kong  
Tel : (852)25680106 Fax(852)90116194 Email: info@callab.com.hk Website:callab.com.hk





# CMA Testing and Certification Laboratories

廠商會檢定中心

## TEST REPORT

Report No. : AY0045504(7)

Date: 16 Aug 2019

Application No. : LY024661(8)



## Calibration Certificate

**Certificate No.: CC0111907**

### 1. Description

Calibration item :	a) Turbidity
Equipment description :	Portable Turbidimeter
Manufacturer :	Hach
Type / Model No. :	2100Q
Serial No. :	17070C059801
Assigned equipment no. :	N/A
Adjustment :	N/A
Remark :	Received with good condition

### 2. Customer information

Customer :	CMA Testing and Certification Laboratories
Address :	Room 1302, Yan Hing Centre, 9-13 Wong Chuk Yeung Street, Fotan, Shatin, NT, Hong Kong
Date of receipt :	19 July 2019

### 3. Date of performance of the calibration

Date of calibration :	22 July 2019
Date of next calibration :	22 October 2019

Authorized Signatory

Warren Yeung

Company Chop:



Certificate issue date: 23 July 2019

- The certificate shall not reproduced except in full without the written approval of CAL LAB LTD
- The Certificate is issued subject to the latest Term and Condition, available assessable at our web site

Page 1 of 2  
cc0111907

Cal Lab Limited

Address: Room 2103, Technology Plaza, 29-35 Sha Tsui Road, Tsuen Wan, NT, Hong Kong  
Tel : (852)25680106 Fax:(852)30116194 Email: [info@callab.com.hk](mailto:info@callab.com.hk) Website: [callab.com.hk](http://callab.com.hk)



# CMA Testing and Certification Laboratories

廠商會檢定中心

## TEST REPORT

Report No. : AY0045504(7)

Date: 16 Aug 2019

Application No. : LY024661(8)



### a) Turbidity

Reference reading (NTU)	Display Reading (NTU)	Error of Indication (%)
Blank	0.03	N/A
10	9.92	0.9
20	20.18	0.9
100	102	2.0
800	808	1.0

### 5. Reference method for calibration

Turbidity	APHA 21e 2130B
-----------	----------------

### 6. Environment condition of calibration

Temperature ; °C	18 – 25 °C
Relative humidity ; %RH	< 75 %RH

\*\*\* End of Certificate \*\*\*

1. The certificate shall not reproduced except in full without the written approval of CAL LAB LTD
2. The Certificate is issued subject to the latest Term and Condition, available assessable at our web site

Page 2 of 2  
cc0111907

Cal Lab Limited

Address: Room 2103, Technology Plaza, 29-35 Sha Tsui Road, Tsuen Wan, NT, Hong Kong  
Tel : (852)25680106 Fax(852)30116194 Email: info@callab.com.hk Website:callab.com.hk

\*\*\*\*\* End of Report \*\*\*\*\*

Page 16 of 16