

**Final Laboratory Testing Report  
for  
Operation Phase Whole Effluent Toxicity Test for  
Advance Disinfection Facilities at Stonecutters Island  
Sewage Treatment Works  
(Contract No. DE/2012/08)**

**Report for the Month of October 2015**

**R&D Corp  
The Hong Kong University of Science and Technology**

# Contents

|                                                                                               |    |
|-----------------------------------------------------------------------------------------------|----|
| <b>Contents</b>                                                                               | 2  |
| <b>1 Introduction</b>                                                                         | 4  |
| 1.1 Background                                                                                | 4  |
| 1.2 Testing laboratory and investigator                                                       | 4  |
| 1.3 Sample                                                                                    | 4  |
| 1.4 Test species                                                                              | 4  |
| 1.5 Test protocols                                                                            | 4  |
| <b>2 Report on Amphipod Acute Toxicity Test</b>                                               | 5  |
| 2.1 Samples storage and pretreatment                                                          | 6  |
| 2.2 Test organism                                                                             | 6  |
| 2.3 Summary of test conditions                                                                | 6  |
| 2.4 Test results                                                                              | 7  |
| 2.5 Summary of water quality parameters monitoring during test                                | 8  |
| 2.6 LC <sub>50</sub> for the amphipod <i>Melita longidactyla</i> and test acceptability       | 8  |
| <b>3 Report on Fish Acute Toxicity Test</b>                                                   | 9  |
| 3.1 Samples storage and pretreatment                                                          | 10 |
| 3.2 Test organism                                                                             | 10 |
| 3.3 Summary of test conditions                                                                | 10 |
| 3.4 Test results                                                                              | 11 |
| 3.5 Summary of water quality parameters monitoring during test                                | 12 |
| 3.6 LC <sub>50</sub> for the fish <i>Lutjanus malabaricus</i> and test acceptability          | 12 |
| <b>4 Report on Barnacle Larvae Acute Toxicity Test</b>                                        | 13 |
| 4.1 Samples storage and pretreatment                                                          | 14 |
| 4.2 Test organism                                                                             | 14 |
| 4.3 Summary of test conditions                                                                | 14 |
| 4.4 Test results                                                                              | 15 |
| 4.5 Summary of water quality parameters monitoring during test                                | 16 |
| 4.6 LC <sub>50</sub> for the barnacle larvae <i>Balanus amphitrite</i> and test acceptability | 16 |
| <b>5 Report on Diatom Growth Inhibition Test (Chronic toxicity test)</b>                      | 17 |
| 5.1 Samples storage and pretreatment                                                          | 18 |
| 5.2 Test organism                                                                             | 18 |
| 5.3 Summary of test conditions                                                                | 18 |
| 5.4 Test results                                                                              | 19 |
| 5.5 Summary of water quality parameters monitoring during test                                | 20 |
| 5.6 IC <sub>50</sub> for the diatom <i>Skeletonema costatum</i> and test acceptability        | 20 |
| <b>6 Report on Shrimp Acute Toxicity Test</b>                                                 | 22 |
| 6.1 Samples storage and pretreatment                                                          | 23 |
| 6.2 Test organism                                                                             | 23 |
| 6.3 Summary of test conditions                                                                | 23 |
| 6.4 Test results                                                                              | 24 |
| 6.5 Summary of water quality parameters monitoring during test                                | 25 |
| 6.6 LC <sub>50</sub> for the shrimp <i>Metapenaeus ensis</i> and test acceptability           | 25 |

|                   |                                                                                    |    |
|-------------------|------------------------------------------------------------------------------------|----|
| <b>7</b>          | <b>Report on Copepod Acute Toxicity Test</b>                                       | 26 |
| 7.1               | Samples storage and pretreatment                                                   | 27 |
| 7.2               | Test organism                                                                      | 27 |
| 7.3               | Summary of test conditions                                                         | 28 |
| 7.4               | Test results                                                                       | 27 |
| 7.5               | Summary of water quality parameters monitoring during test                         | 29 |
| 7.6               | LC <sub>50</sub> for the copepod <i>Tigriopus japonicus</i> and test acceptability | 29 |
| <b>8</b>          | <b>Conclusion</b>                                                                  | 30 |
| <b>Appendix A</b> | <b>Monitoring Data for Amphipod Acute Toxicity Test</b>                            | 32 |
| <b>Appendix B</b> | <b>Monitoring Data for Fish Acute Toxicity Test</b>                                | 35 |
| <b>Appendix C</b> | <b>Monitoring Data for Barnacle Larvae Acute Toxicity Test</b>                     | 38 |
| <b>Appendix D</b> | <b>Monitoring Data for Diatom Growth Inhibition Test</b>                           | 41 |
| <b>Appendix E</b> | <b>Monitoring Data for Shrimp Acute Toxicity Test</b>                              | 45 |
| <b>Appendix F</b> | <b>Monitoring Data for Copepod Acute Toxicity Test</b>                             | 48 |

# 1. Introduction

## 1.1. Background

The whole effluent toxicity tests (WETT) were carried out under the requirements of Drainage Service Department (DSD).

## 1.2. Testing laboratory and investigator

The following tests were carried out in the Coastal Marine Laboratory (CML), Hong Kong University of Science and Technology.

**Principle investigator:** Prof. Wen-Xiong WANG

**Phone number:** (852) 2358-7346

**Fax number:** (852) 2358-1559

**Address:** Division of Life Science, Hong Kong University of Science and Technology, Clear Water Bay, Kowloon, Hong Kong

## 1.3. Sample

A 24-hour flow-weighted composite effluent sample was collected from Stonecutters Island Sewage Treatment Works (SCISTW) on October 27<sup>th</sup>, 2015. Effluent sample was shipped immediately to the testing laboratory on the same day of collection and stored at 4 °C until use. Toxicity testings were started on the same day after sample collection.

## 1.4. Test species

The following test species were included in the WETT:

- Amphipod (*Melita longidactyla*)
- Fish (*Lutjanus malabaricus*)
- Barnacle larvae (*Balanus amphitrite*)
- Diatom (*Skeletonema costatum*)
- Shrimp (*Metapenaeus ensis*)
- Copepod (*Tigriopus japonicus*)

## 1.5. Test protocols

The WETT testing methods and procedures follow those documented in “Consultancy Study on Fisheries and Marine Ecological Criteria for Impact Assessment-Final Report” commissioned by Agriculture, Fisheries and Conservation Department (AFCD), as indicated in tender addendum No. 1 by Drainage Services Department (DSD).

The report is certified by:

\_\_\_\_\_ (Prof. Wen-Xiong WANG)      Date: \_\_\_\_\_

## **2. Report on Amphipod Acute Toxicity Test**

# Test report

## 2.1. Samples storage and pretreatment

Effluent sample was thoroughly mixed and passed through 2-mm mesh to remove the large debris. Effluent was added with ocean salt in order to raise the salinity to the required level (30‰) and then aerated moderately such that the dissolved oxygen (DO) reached saturation prior to use. Salinity control was set up to monitor if there was adverse effect on the test organisms.

## 2.2. Test organism

Species: Amphipod (*Melita longidactyla*).  
Source: Collected from local coastal waters from Sai Kung  
Size/age: 0.5-0.7 cm  
Acclimatization: Acclimatized in fully aerated seawater (temperature: 22±1°C, salinity: 30‰) at least 48 hours in the laboratory prior to test. Fed with green algae *Ulva lactuca*.

## 2.3. Summary of test conditions

Type of test: Static  
Duration: 48 h, 03/11/2015-05/11/2015  
Dilution seawater source: Seawater collected from a pristine site in Clear Water Bay, Sai Kung, Hong Kong  
Dilution seawater pretreatment: Filtered through 0.22 µm membrane  
Testing temperature: 22±1 °C  
Lighting: Continuous  
Salinity: 30‰  
Testing chamber: Pre-cleaned 150 mL glass flask  
Feeding: None  
Number of organisms per replicate: 10  
Replicate number: 4  
Volume of test medium: 100 mL  
Aeration: Moderate, around 100 bubbles/min  
Reference toxicant: CdCl<sub>2</sub>  
Positive control: 48 h acute toxicity test  
Salinity control: Prepared with ocean salt adding into de-ionized water, salinity: 30‰

## 2.4. Test results

Table 1. Survival of amphipods after 48 hours.

| Treatment        | Effluent concentration (%) | Number of living amphipods after 48 hour (individuals) |             |             |             |      |     |
|------------------|----------------------------|--------------------------------------------------------|-------------|-------------|-------------|------|-----|
|                  |                            | Replicate 1                                            | Replicate 2 | Replicate 3 | Replicate 4 | Mean | SD  |
| Negative control | 0                          | 10                                                     | 10          | 10          | 10          | 10.0 | 0.0 |
| Salinity control | 0                          | 10                                                     | 9           | 10          | 10          | 9.8  | 0.5 |
| Concentration 1  | 6.5                        | 10                                                     | 10          | 8           | 10          | 9.5  | 1.0 |
| Concentration 2  | 12.5                       | 8                                                      | 10          | 8           | 10          | 9.0  | 1.2 |
| Concentration 3  | 25                         | 10                                                     | 9           | 7           | 7           | 8.3  | 1.5 |
| Concentration 4  | 50                         | 5                                                      | 7           | 5           | 6           | 5.8  | 1.0 |
| Concentration 5  | 100                        | 0                                                      | 2           | 1           | 1           | 1.0  | 0.8 |

Table 2. Survival percentage of amphipods after 48 hours.

| Treatment        | Effluent concentration (%) | Percentage of living amphipods after 48 hour (%) |             |             |             |       |      |
|------------------|----------------------------|--------------------------------------------------|-------------|-------------|-------------|-------|------|
|                  |                            | Replicate 1                                      | Replicate 2 | Replicate 3 | Replicate 4 | Mean  | SD   |
| Negative control | 0                          | 100.0                                            | 100.0       | 100.0       | 100.0       | 100.0 | 0.0  |
| Salinity control | 0                          | 100.0                                            | 90.0        | 100.0       | 100.0       | 97.5  | 5.0  |
| Concentration 1  | 6.5                        | 100.0                                            | 100.0       | 80.0        | 100.0       | 95.0  | 10.0 |
| Concentration 2  | 12.5                       | 80.0                                             | 100.0       | 80.0        | 100.0       | 90.0  | 11.5 |
| Concentration 3  | 25                         | 100.0                                            | 90.0        | 70.0        | 70.0        | 82.5  | 15.0 |
| Concentration 4  | 50                         | 50.0                                             | 70.0        | 50.0        | 60.0        | 57.5  | 9.6  |
| Concentration 5  | 100                        | 0.0                                              | 20.0        | 10.0        | 10.0        | 10.0  | 8.2  |

## 2.5. Summary of water quality parameters monitoring during test.

Table 3. Summary of water quality parameters during amphipod acute toxicity test.

| Water quality parameters                                 | Effluent concentration (%) |                  |           |           |           |           |           |
|----------------------------------------------------------|----------------------------|------------------|-----------|-----------|-----------|-----------|-----------|
|                                                          | Negative control           | Salinity control | 6.5       | 12.5      | 25        | 50        | 100       |
| Salinity (‰)                                             | 30.0                       | 30.0             | 30.0      | 30.0      | 30.0      | 30.0      | 30.0      |
| Dissolved oxygen (mg L <sup>-1</sup> )                   | 6.0-6.8                    | 6.2-6.7          | 6.0-7.0   | 6.0-6.8   | 6.0-7.0   | 6.1-7.1   | 6.1-6.6   |
| Temperature (°C)                                         | 22.0                       | 22.0             | 22.0      | 22.0      | 22.0      | 22.0      | 22.0      |
| pH                                                       | 7.9-8.2                    | 7.9-8.1          | 7.9-8.1   | 8.0-8.2   | 8.0-8.1   | 8.0-8.2   | 7.6-8.1   |
| Total ammonia (start/end, mg L <sup>-1</sup> )           | 0.06/0.31                  | 0.05/0.15        | 0.93/0.56 | 2.16/1.68 | 4.32/4.01 | 9.62/7.82 | 21.3/16.3 |
| Total sulfide (start/end, mg L <sup>-1</sup> )           | <0.1                       | <0.1             | <0.1      | <0.1      | <0.1      | <0.1      | <0.1      |
| Total residual chlorine (start/end, mg L <sup>-1</sup> ) | <0.02                      | <0.02            | <0.02     | <0.02     | <0.02     | <0.02     | <0.02     |
| Total suspended solid (start/end, mg L <sup>-1</sup> )   | 4.1/3.5                    | 3.6/4.6          | 4.1/5.1   | 6.8/5.2   | 13.4/7.6  | 20.7/16.5 | 44.6/36.2 |

## 2.6. LC<sub>50</sub> for the amphipod *Melita longidactyla* and test acceptability

Table 4. LC<sub>50</sub> for the amphipods and test acceptability.

| Parameter                                          | Value                        | Control limit                              |
|----------------------------------------------------|------------------------------|--------------------------------------------|
| Calculated LC <sub>50</sub>                        | (57.8±3.6)%                  | NA                                         |
| Negative control survival                          | 100.0%                       | >90%                                       |
| Reference toxicant 48-h acute test                 | 1.24 mg L <sup>-1</sup>      | 1.25±0.15 mg L <sup>-1</sup>               |
| 95% of confidence range of reference toxicant test | 1.12-1.41 mg L <sup>-1</sup> | NA                                         |
| Daily temperature variation                        | <0.5 °C                      | Average daily temperature variation: ±1 °C |
| Dissolved oxygen concentration                     | >6.0 mg L <sup>-1</sup>      | >4 mg L <sup>-1</sup>                      |

NA: Not applicable



### **3. Report on Fish Acute Toxicity Test**

# Test report

## 3.1. Samples storage and pretreatment

Effluent sample was thoroughly mixed and passed through 2-mm mesh to remove large debris. Effluent was added with ocean salt in order to raise the salinity to the required level (30‰) and then aerated moderately such that the dissolved oxygen (DO) reached saturation prior to use. Salinity control was set up to monitor if there was adverse effect on the test organisms.

## 3.2. Test organism

|                  |                                                                                                                                                                               |
|------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Species          | Fish ( <i>Lutjanus malabaricus</i> )                                                                                                                                          |
| Source:          | Purchased from local contracted fish farm                                                                                                                                     |
| Size/age:        | 5-8 cm                                                                                                                                                                        |
| Acclimatization: | Acclimatized in fully aerated seawater (temperature: 22±1°C, salinity: 30‰) at least 48 hours in laboratory prior to test. Fed with fresh shrimp purchased from local market. |

## 3.3. Summary of test conditions

|                                    |                                                                                 |
|------------------------------------|---------------------------------------------------------------------------------|
| Type of test:                      | Static                                                                          |
| Duration:                          | 48 h, 09/11/2015-11/11/2015                                                     |
| Dilution seawater source:          | Seawater collected from a pristine site in Clear Water Bay, Sai Kung, Hong Kong |
| Dilution seawater pretreatment:    | Filtered through 5 µm filtration bag                                            |
| Testing temperature:               | 22±1 °C                                                                         |
| Lighting:                          | Continuous                                                                      |
| Salinity:                          | 30‰                                                                             |
| Testing chamber:                   | Pre-cleaned 20 L tank                                                           |
| Feeding:                           | None                                                                            |
| Number of organisms per replicate: | 10                                                                              |
| Replicate number:                  | 4                                                                               |
| Volume of test medium:             | 20 L                                                                            |
| Aeration:                          | Moderate, with air stone                                                        |
| Reference toxicant:                | CdCl <sub>2</sub>                                                               |
| Positive control:                  | 48 h acute toxicity test                                                        |
| Salinity control:                  | Prepared with ocean salt adding into de-ionized water, salinity: 30‰            |

### 3.4. Test results

Table 1. Survival of fish after 48 hours.

| Treatment        | Effluent concentration (%) | Number of living fish after 48 hour (individuals) |             |             |             |      |     |
|------------------|----------------------------|---------------------------------------------------|-------------|-------------|-------------|------|-----|
|                  |                            | Replicate 1                                       | Replicate 2 | Replicate 3 | Replicate 4 | Mean | SD  |
| Negative control | 0                          | 10                                                | 10          | 10          | 10          | 10.0 | 0.0 |
| Salinity control | 0                          | 10                                                | 10          | 10          | 10          | 10.0 | 0.0 |
| Concentration 1  | 6.5                        | 10                                                | 10          | 10          | 10          | 10.0 | 0.0 |
| Concentration 2  | 12.5                       | 10                                                | 10          | 10          | 10          | 10.0 | 0.0 |
| Concentration 3  | 25                         | 10                                                | 10          | 10          | 10          | 10.0 | 0.0 |
| Concentration 4  | 50                         | 10                                                | 10          | 10          | 10          | 10.0 | 0.0 |
| Concentration 5  | 100                        | 0                                                 | 2           | 2           | 3           | 1.8  | 1.3 |

Table 2. Survival percentage of fish after 48 hours.

| Treatment        | Effluent concentration (%) | Percentage of living fish after 48 hour (%) |             |             |             |       |      |
|------------------|----------------------------|---------------------------------------------|-------------|-------------|-------------|-------|------|
|                  |                            | Replicate 1                                 | Replicate 2 | Replicate 3 | Replicate 4 | Mean  | SD   |
| Negative control | 0                          | 100.0                                       | 100.0       | 100.0       | 100.0       | 100.0 | 0.0  |
| Salinity control | 0                          | 100.0                                       | 100.0       | 100.0       | 100.0       | 100.0 | 0.0  |
| Concentration 1  | 6.5                        | 100.0                                       | 100.0       | 100.0       | 100.0       | 100.0 | 0.0  |
| Concentration 2  | 12.5                       | 100.0                                       | 100.0       | 100.0       | 100.0       | 100.0 | 0.0  |
| Concentration 3  | 25                         | 100.0                                       | 100.0       | 100.0       | 100.0       | 100.0 | 0.0  |
| Concentration 4  | 50                         | 100.0                                       | 100.0       | 100.0       | 100.0       | 100.0 | 0.0  |
| Concentration 5  | 100                        | 0.0                                         | 20.0        | 20.0        | 30.0        | 17.5  | 12.6 |

### 3.5. Summary of water quality parameters monitoring during test

Table 3. Summary of water quality parameters during fish acute toxicity test.

| Water quality parameters                                 | Effluent concentration (%) |                  |           |           |           |           |           |
|----------------------------------------------------------|----------------------------|------------------|-----------|-----------|-----------|-----------|-----------|
|                                                          | Negative control           | Salinity control | 6.5       | 12.5      | 25        | 50        | 100       |
| Salinity (‰)                                             | 30.0                       | 30.0             | 30.0      | 30.0      | 30.0      | 30.0      | 30.0      |
| Dissolved oxygen (mg L <sup>-1</sup> )                   | 6.3-7.2                    | 6.2-7.0          | 6.2-7.2   | 6.2-7.1   | 6.3-7.1   | 6.6-7.2   | 6.4-7.1   |
| Temperature (°C)                                         | 22.0                       | 22.0             | 22.0      | 22.0      | 22.0      | 22.0      | 22.0      |
| pH                                                       | 7.9-8.1                    | 8.0-8.2          | 7.9-8.0   | 7.9-8.2   | 7.9-8.2   | 8.0-8.1   | 7.6-8.0   |
| Total ammonia (start/end, mg L <sup>-1</sup> )           | 0.08/0.15                  | 0.06/0.13        | 1.51/1.22 | 2.43/2.06 | 5.87/4.21 | 10.9/8.2  | 23.8/20.3 |
| Total sulfide (start/end, mg L <sup>-1</sup> )           | <0.1                       | <0.1             | <0.1      | <0.1      | <0.1      | <0.1      | <0.1      |
| Total residual chlorine (start/end, mg L <sup>-1</sup> ) | <0.02                      | <0.02            | <0.02     | <0.02     | <0.02     | <0.02     | <0.02     |
| Total suspended solid (mg L <sup>-1</sup> )              | 4.0/5.1                    | 5.1/3.9          | 7.1/7.6   | 6.9/8.1   | 10.2/8.2  | 17.4/13.8 | 38.9/19.1 |

### 3.6. LC<sub>50</sub> for the fish *Lutjanus malabaricus* and test acceptability

Table 4. LC<sub>50</sub> for the fish and test acceptability.

| Parameter                                          | Value                        | Control limit                               |
|----------------------------------------------------|------------------------------|---------------------------------------------|
| Calculated LC <sub>50</sub>                        | (80.5±2.0)%                  | NA                                          |
| Negative survival                                  | 100.0%                       | >90%                                        |
| Reference toxicant 48-h acute test                 | 15.8 mg L <sup>-1</sup>      | 14.6±1.78 mg L <sup>-1</sup>                |
| 95% of confidence range of reference toxicant test | 14.6-17.9 mg L <sup>-1</sup> | NA                                          |
| Daily temperature variation                        | <0.5 °C                      | Average daily temperature variation: ± 1 °C |
| Dissolved oxygen concentration                     | >6.5 mg L <sup>-1</sup>      | >4 mg L <sup>-1</sup>                       |

NA: Not applicable

## **4. Report on Barnacle Larvae Acute Toxicity Test**

# Test report

## 4.1. Samples storage and pretreatment

Effluent sample was thoroughly mixed and passed through 5 µm membrane filter to remove large debris. Effluent was added with ocean salt in order to raise the salinity to the required level (30‰) and then aerated moderately to dissolved oxygen (DO) saturation prior to use. Salinity control was set up to monitor if there was adverse effect on the test organisms.

## 4.2. Test organism

|                  |                                                                                                                                                                                                          |
|------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Species          | Barnacle larvae ( <i>Balanus amphitrite</i> ).                                                                                                                                                           |
| Source:          | Introduced from adult barnacles collected from Sai Kung                                                                                                                                                  |
| Size/age:        | Stage II                                                                                                                                                                                                 |
| Acclimatization: | Acclimatized in fully aerated seawater held in 500 mL glass beaker (temperature: 22±1°C, salinity: 30‰) for at least 24 hours in laboratory prior to test. Fed with diatom <i>Chaetoceros gracilis</i> . |

## 4.3. Summary of test conditions

|                                    |                                                                                 |
|------------------------------------|---------------------------------------------------------------------------------|
| Type of test:                      | Static                                                                          |
| Duration:                          | 48 h, 04/11/2015-06/11/2015                                                     |
| Dilution seawater source:          | Seawater collected from a pristine site in Clear Water Bay, Sai Kung, Hong Kong |
| Dilution seawater pretreatment:    | Filtered through 0.22 µm membrane                                               |
| Testing temperature:               | 22±1 °C                                                                         |
| Lighting:                          | Continuous                                                                      |
| Salinity:                          | 30‰                                                                             |
| Testing chamber:                   | Pre-cleaned 50 mL glass beaker                                                  |
| Feeding:                           | None                                                                            |
| Number of organisms per replicate: | 20                                                                              |
| Replicate number:                  | 4                                                                               |
| Volume of test medium:             | 20 mL                                                                           |
| Aeration:                          | Moderate, around 100 bubbles/min                                                |
| Reference toxicant:                | CdCl <sub>2</sub>                                                               |
| Positive control:                  | 48 h acute toxicity test                                                        |
| Salinity control:                  | Prepared with ocean salt adding into de-ionized water, salinity: 30‰            |

#### 4.4. Test results

Table 1. Survival of barnacle larvae after 48 hours

| Treatment        | Effluent concentration (%) | Number of living barnacle larvae after 48 hour (individuals) |             |             |             |      |     |
|------------------|----------------------------|--------------------------------------------------------------|-------------|-------------|-------------|------|-----|
|                  |                            | Replicate 1                                                  | Replicate 2 | Replicate 3 | Replicate 4 | Mean | SD  |
| Negative control | 0                          | 20                                                           | 19          | 20          | 20          | 19.8 | 0.5 |
| Salinity control | 0                          | 20                                                           | 20          | 19          | 19          | 19.5 | 0.6 |
| Concentration 1  | 6.5                        | 14                                                           | 17          | 16          | 15          | 15.5 | 1.3 |
| Concentration 2  | 12.5                       | 11                                                           | 10          | 13          | 12          | 11.5 | 1.3 |
| Concentration 3  | 25                         | 9                                                            | 11          | 12          | 9           | 10.3 | 1.5 |
| Concentration 4  | 50                         | 5                                                            | 4           | 2           | 3           | 3.5  | 1.3 |
| Concentration 5  | 100                        | 0                                                            | 0           | 0           | 0           | 0.0  | 0.0 |

Table 2. Survival percentage of barnacle larvae after 48 hours.

| Treatment        | Effluent concentration (%) | Percentage of living barnacle larvae after 48 hour (%) |             |             |             |      |     |
|------------------|----------------------------|--------------------------------------------------------|-------------|-------------|-------------|------|-----|
|                  |                            | Replicate 1                                            | Replicate 2 | Replicate 3 | Replicate 4 | Mean | SD  |
| Negative control | 0                          | 100.0                                                  | 95.0        | 100.0       | 100.0       | 98.8 | 2.5 |
| Salinity control | 0                          | 100.0                                                  | 100.0       | 95.0        | 95.0        | 97.5 | 2.9 |
| Concentration 1  | 6.5                        | 70.0                                                   | 85.0        | 80.0        | 75.0        | 77.5 | 6.5 |
| Concentration 2  | 12.5                       | 55.0                                                   | 50.0        | 65.0        | 60.0        | 57.5 | 6.5 |
| Concentration 3  | 25                         | 45.0                                                   | 55.0        | 60.0        | 45.0        | 51.3 | 7.5 |
| Concentration 4  | 50                         | 25.0                                                   | 20.0        | 10.0        | 15.0        | 17.5 | 6.5 |
| Concentration 5  | 100                        | 0.0                                                    | 0.0         | 0.0         | 0.0         | 0.0  | 0.0 |

#### 4.5. Summary of water quality parameters monitoring during test

Table 3. Summary of water quality parameters during barnacle larvae acute toxicity test

| Water quality parameters                                 | Effluent concentration (%) |                  |           |           |           |           |           |
|----------------------------------------------------------|----------------------------|------------------|-----------|-----------|-----------|-----------|-----------|
|                                                          | Negative control           | Salinity control | 6.5       | 12.5      | 25        | 50        | 100       |
| Salinity (‰)                                             | 30.0                       | 30.0             | 30.0      | 30.0      | 30.0      | 30.0      | 30.0      |
| Dissolved oxygen (mg L <sup>-1</sup> )                   | 6.2-6.6                    | 6.2-6.6          | 6.2-6.6   | 6.3-6.6   | 6.4-6.6   | 6.2-6.5   | 6.2-6.6   |
| Temperature (°C)                                         | 22.0                       | 22.0             | 22.0      | 22.0      | 22.0      | 22.0      | 22.0      |
| pH                                                       | 8.0-8.2                    | 8.0-8.1          | 8.1-8.2   | 7.9-8.2   | 7.9-8.2   | 8.0-8.2   | 7.6-7.9   |
| Total ammonia (start/end, mg L <sup>-1</sup> )           | 0.06/0.02                  | 0.06/0.07        | 1.54/1.21 | 2.27/2.08 | 4.94/4.22 | 10.6/10.2 | 21.1/20.9 |
| Total sulfide (start/end, mg L <sup>-1</sup> )           | <0.1                       | <0.1             | <0.1      | <0.1      | <0.1      | <0.1      | <0.1      |
| Total residual chlorine (start/end, mg L <sup>-1</sup> ) | <0.02                      | <0.02            | <0.02     | <0.02     | <0.02     | <0.02     | <0.02     |
| Total suspended solid (mg L <sup>-1</sup> )              | <0.2                       | <0.2             | <0.2      | <0.2      | <0.2      | <0.2      | <0.2      |

#### 4.6. LC<sub>50</sub> for the barnacle larvae *Balanus amphitrite* and test acceptability

Table 4. LC<sub>50</sub> for the barnacle larvae and test acceptability

| Parameter                                           | Value                        | Control limit                               |
|-----------------------------------------------------|------------------------------|---------------------------------------------|
| Calculated LC <sub>50</sub>                         | (25.8±2.6)%                  | NA                                          |
| Negative survival                                   | 98.8%                        | >90%                                        |
| Reference toxicant 48-h acute test                  | 0.94 mg L <sup>-1</sup>      | 1.04±0.11 mg L <sup>-1</sup>                |
| 95% of confidence range of reference toxicant test: | 0.86-1.15 mg L <sup>-1</sup> | NA                                          |
| Daily temperature variation                         | <0.5 °C                      | Average daily temperature variation: ± 1 °C |
| Dissolved oxygen concentration                      | >6.2 mg L <sup>-1</sup>      | >4 mg L <sup>-1</sup>                       |

NA: Not applicable



## **5. Report on Diatom Growth Inhibition Test (Chronic toxicity test)**

# Test report

## 5.1. Samples storage and pretreatment

Effluent sample was thoroughly mixed and passed through 5 µm membrane filter to remove large debris. Effluent was added with ocean salt in order to raise the salinity to the required level (30‰) and then aerated moderately to dissolved oxygen (DO) saturation prior to use. Salinity control was set up to monitor if there was adverse effect on the test organisms.

## 5.2. Test organism

|                  |                                                                                                                  |
|------------------|------------------------------------------------------------------------------------------------------------------|
| Species          | Diatom ( <i>Skeletonema costatum</i> )                                                                           |
| Source:          | Grown from laboratory culture obtained from Coastal Marine Lab, Hong Kong University of Science and Technology   |
| Size/age:        | Log growth phase                                                                                                 |
| Acclimatization: | Grown in 250 mL glass flask (temperature: 22±1°C, salinity: 30‰, 3000 lux) for at least two weeks prior to test. |

## 5.3. Summary of test conditions

|                                 |                                                                                 |
|---------------------------------|---------------------------------------------------------------------------------|
| Type of test:                   | Static                                                                          |
| Duration:                       | 7 days, 03/11/2015-10/11/2015                                                   |
| Dilution seawater source:       | Seawater collected from a pristine site in Clear Water Bay, Sai Kung, Hong Kong |
| Dilution seawater pretreatment: | Filtered through 0.22 µm membrane                                               |
| Testing temperature:            | 22±1 °C                                                                         |
| Lighting:                       | 12 h light/12 h dark cycle, 3000±500 lux                                        |
| Salinity:                       | 30‰                                                                             |
| Testing chamber:                | Pre-cleaned 100 mL glass beaker                                                 |
| Initial cell density:           | (5.0±0.4)×10 <sup>4</sup> cell mL <sup>-1</sup>                                 |
| Replicate number:               | 4                                                                               |
| Volume of test medium:          | 25 mL                                                                           |
| Aeration:                       | None                                                                            |
| Reference toxicant:             | CdCl <sub>2</sub>                                                               |
| Positive control:               | 7-day IC <sub>50</sub> toxicity test                                            |
| Salinity control:               | Prepared with ocean salt adding into de-ionized water, salinity: 30‰            |

#### 5.4. Test results

Table 1. Cell density of diatom *Skeletonema costatum* at the beginning and end of growth inhibition test. Initial cell density:  $(5.0 \pm 0.4) \times 10^4$  cell mL<sup>-1</sup>.

| Treatment        | Effluent concentration (%) | Cell density after 7-day growth ( $\times 10^6$ cell mL <sup>-1</sup> ) |             |             |             |      |      |
|------------------|----------------------------|-------------------------------------------------------------------------|-------------|-------------|-------------|------|------|
|                  |                            | Replicate 1                                                             | Replicate 2 | Replicate 3 | Replicate 4 | Mean | SD   |
| Negative control | 0                          | 1.30                                                                    | 1.30        | 1.36        | 1.24        | 1.30 | 0.05 |
| Salinity control | 0                          | 1.42                                                                    | 1.31        | 1.32        | 1.37        | 1.36 | 0.05 |
| Concentration 1  | 2.5                        | 1.46                                                                    | 1.41        | 1.44        | 1.51        | 1.46 | 0.04 |
| Concentration 2  | 5                          | 1.96                                                                    | 2.03        | 1.89        | 1.92        | 1.95 | 0.06 |
| Concentration 3  | 10                         | 1.17                                                                    | 1.31        | 1.24        | 1.22        | 1.24 | 0.06 |
| Concentration 4  | 25                         | 0.87                                                                    | 0.92        | 0.88        | 0.95        | 0.91 | 0.04 |
| Concentration 5  | 50                         | 0.59                                                                    | 0.55        | 0.52        | 0.56        | 0.56 | 0.03 |
| Concentration 6  | 100                        | 0.00                                                                    | 0.00        | 0.00        | 0.00        | 0.00 | 0.00 |

Table 2. Growth rate of *Skeletonema costatum* within 7 days.

| Treatment        | Effluent concentration (%) | 7-day average growth rate (d <sup>-1</sup> ) |             |             |             |      |      |
|------------------|----------------------------|----------------------------------------------|-------------|-------------|-------------|------|------|
|                  |                            | Replicate 1                                  | Replicate 2 | Replicate 3 | Replicate 4 | Mean | SD   |
| Negative control | 0                          | 0.47                                         | 0.47        | 0.47        | 0.46        | 0.47 | 0.01 |
| Salinity control | 0                          | 0.48                                         | 0.47        | 0.47        | 0.47        | 0.47 | 0.01 |
| Concentration 1  | 2.5                        | 0.48                                         | 0.48        | 0.48        | 0.49        | 0.48 | 0.00 |
| Concentration 2  | 5                          | 0.52                                         | 0.53        | 0.52        | 0.52        | 0.52 | 0.00 |
| Concentration 3  | 10                         | 0.45                                         | 0.47        | 0.46        | 0.46        | 0.46 | 0.01 |
| Concentration 4  | 25                         | 0.41                                         | 0.42        | 0.41        | 0.42        | 0.41 | 0.01 |
| Concentration 5  | 50                         | 0.35                                         | 0.34        | 0.34        | 0.34        | 0.34 | 0.01 |
| Concentration 6  | 100                        | 0.00                                         | 0.00        | 0.00        | 0.00        | 0.00 | 0.00 |

### 5.5. Summary of water quality parameters monitoring during test

Table 3. Summary of water quality parameters during diatom growth inhibition test

| Water quality parameters                                 | Effluent concentration (%) |                  |           |           |           |           |           |           |
|----------------------------------------------------------|----------------------------|------------------|-----------|-----------|-----------|-----------|-----------|-----------|
|                                                          | Negative control           | Salinity control | 2.5       | 5.0       | 10        | 25        | 50        | 100       |
| Salinity (‰)                                             | 30.0                       | 30.0             | 30.0      | 30.0      | 30.0      | 30.0      | 30.0      | 30.0      |
| Dissolved oxygen (mg L <sup>-1</sup> )                   | 6.3-9.3                    | 6.5-10.2         | 6.4-9.5   | 6.5-9.8   | 6.6-10.1  | 6.5-9.5   | 6.4-8.8   | 6.2-7.2   |
| Temperature (°C)                                         | 22.0                       | 22.0             | 22.0      | 22.0      | 22.0      | 22.0      | 22.0      | 22.0      |
| pH                                                       | 7.9-8.6                    | 7.9-8.8          | 8.0-8.5   | 8.0-9.0   | 8.0-8.8   | 8.1-8.7   | 8.0-8.7   | 7.9-8.1   |
| Total ammonia (start/end, mg L <sup>-1</sup> )           | 0.09/0.06                  | 0.0/0.05         | 0.36/0.08 | 1.09/0.09 | 2.28/0.13 | 4.44/0.21 | 9.92/7.67 | 18.7/17.2 |
| Total sulfide (start/end, mg L <sup>-1</sup> )           | <0.1                       | <0.1             | <0.1      | <0.1      | <0.1      | <0.1      | <0.1      | <0.1      |
| Total residual chlorine (start/end, mg L <sup>-1</sup> ) | <0.02                      | <0.02            | <0.02     | <0.02     | <0.02     | <0.02     | <0.02     | <0.02     |
| Total suspended solid (mg L <sup>-1</sup> )              | <0.2                       | <0.2             | <0.2      | <0.2      | <0.2      | <0.2      | <0.2      | <0.2      |

### 5.6. IC<sub>50</sub> for the diatom *Skeletonema costatum* and test acceptability

Table 4. IC<sub>50</sub>, none observed effect concentration (NOEC) for the diatom and test acceptability

| Parameter                                          | Value                        | Control limit                               |
|----------------------------------------------------|------------------------------|---------------------------------------------|
| Calculated IC <sub>50</sub>                        | (64.2±0.3)%                  | NA                                          |
| None observed effect concentration (NOEC)          | 2.5%                         | -                                           |
| Reference toxicant 7-day test:                     | 0.13 mg L <sup>-1</sup>      | 0.13±0.02 mg L <sup>-1</sup>                |
| 95% of confidence range of reference toxicant test | 0.10-0.17 mg L <sup>-1</sup> | NA                                          |
| Temperature variation                              | <0.5 °C                      | Average daily temperature variation: ± 1 °C |

NA: Not applicable

## **6. Report on Shrimp Acute Toxicity Test**

# Test report

## 6.1. Samples storage and pretreatment

Effluent sample was thoroughly mixed and passed through 2-mm mesh to remove the large debris. Effluent was added with ocean salt in order to raise the salinity to 25‰ and then aerated moderately such that the dissolved oxygen (DO) reached saturation prior to use. Salinity control was set up to monitor if there was adverse effect on the test organisms.

## 6.2. Test organism

|                  |                                                                                                                                                                  |
|------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Species          | Shrimp ( <i>Metapenaeus ensis</i> ).                                                                                                                             |
| Source:          | Purchased from contracted fish dealer                                                                                                                            |
| Size/age:        | 5-7 cm                                                                                                                                                           |
| Acclimatization: | Acclimatized in fully aerated seawater (temperature: 22±1°C, salinity: 25‰) at least 48 hours in the laboratory prior to test. Fed with commercial shrimp feeds. |

## 6.3. Summary of test conditions

|                                    |                                                                                 |
|------------------------------------|---------------------------------------------------------------------------------|
| Type of test:                      | Static                                                                          |
| Duration:                          | 48 h, 04/11/2015-06/11/2015                                                     |
| Dilution seawater source:          | Seawater collected from a pristine site in Clear Water Bay, Sai Kung, Hong Kong |
| Dilution seawater pretreatment:    | Filtered through 0.22 µm membrane                                               |
| Testing temperature:               | 22±1 °C                                                                         |
| Lighting:                          | Continuous                                                                      |
| Salinity:                          | 25‰                                                                             |
| Testing chamber:                   | Pre-cleaned 20 L tank                                                           |
| Feeding:                           | None                                                                            |
| Number of organisms per replicate: | 10                                                                              |
| Replicate number:                  | 4                                                                               |
| Volume of test medium:             | 10 L                                                                            |
| Aeration:                          | Moderate, with air stone                                                        |
| Reference toxicant:                | CdCl <sub>2</sub>                                                               |
| Positive control:                  | 48 h acute toxicity test                                                        |
| Salinity control:                  | Prepared with ocean salt adding into de-ionized water, salinity: 25‰            |

#### 6.4. Test results

Table 1. Survival of shrimps after 48 hours.

| Treatment        | Effluent concentration (%) | Number of living shrimps after 48 hour (individuals) |             |             |             |      |     |
|------------------|----------------------------|------------------------------------------------------|-------------|-------------|-------------|------|-----|
|                  |                            | Replicate 1                                          | Replicate 2 | Replicate 3 | Replicate 4 | Mean | SD  |
| Negative control | 0                          | 10                                                   | 10          | 10          | 10          | 10.0 | 0.0 |
| Salinity control | 0                          | 8                                                    | 10          | 10          | 10          | 9.5  | 1.0 |
| Concentration 1  | 6.5                        | 10                                                   | 10          | 10          | 10          | 10.0 | 0.0 |
| Concentration 2  | 12.5                       | 8                                                    | 10          | 10          | 8           | 9.0  | 1.2 |
| Concentration 3  | 25                         | 10                                                   | 7           | 9           | 9           | 8.8  | 1.3 |
| Concentration 4  | 50                         | 10                                                   | 7           | 7           | 8           | 8.0  | 1.4 |
| Concentration 5  | 100                        | 0                                                    | 0           | 0           | 1           | 0.3  | 0.5 |

Table 2. Survival percentage of shrimps after 48 hours.

| Treatment        | Effluent concentration (%) | Percentage of living shrimps after 48 hour (%) |             |             |             |       |      |
|------------------|----------------------------|------------------------------------------------|-------------|-------------|-------------|-------|------|
|                  |                            | Replicate 1                                    | Replicate 2 | Replicate 3 | Replicate 4 | Mean  | SD   |
| Negative control | 0                          | 100.0                                          | 100.0       | 100.0       | 100.0       | 100.0 | 0.0  |
| Salinity control | 0                          | 80.0                                           | 100.0       | 100.0       | 100.0       | 95.0  | 10.0 |
| Concentration 1  | 6.5                        | 100.0                                          | 100.0       | 100.0       | 100.0       | 100.0 | 0.0  |
| Concentration 2  | 12.5                       | 80.0                                           | 100.0       | 100.0       | 80.0        | 90.0  | 11.5 |
| Concentration 3  | 25                         | 100.0                                          | 70.0        | 90.0        | 90.0        | 87.5  | 12.6 |
| Concentration 4  | 50                         | 100.0                                          | 70.0        | 70.0        | 80.0        | 80.0  | 14.1 |
| Concentration 5  | 100                        | 0.0                                            | 0.0         | 0.0         | 10.0        | 2.5   | 5.0  |



### 6.5. Summary of water quality parameters monitoring during test.

Table 3. Summary of water quality parameters during shrimp acute toxicity test.

| Water quality parameters                                 | Effluent concentration (%) |                  |           |           |           |           |           |
|----------------------------------------------------------|----------------------------|------------------|-----------|-----------|-----------|-----------|-----------|
|                                                          | Negative control           | Salinity control | 6.5       | 12.5      | 25        | 50        | 100       |
| Salinity (‰)                                             | 25.0                       | 25.0             | 25.0      | 25.0      | 25.0      | 25.0      | 25.0      |
| Dissolved oxygen (mg L <sup>-1</sup> )                   | 6.3-7.0                    | 6.3-7.1          | 6.5-7.3   | 6.5-7.2   | 6.3-7.1   | 6.8-7.3   | 6.5-7.3   |
| Temperature (°C)                                         | 22.0                       | 22.0             | 22.0      | 22.0      | 22.0      | 22.0      | 22.0      |
| pH                                                       | 7.9-8.1                    | 7.9-8.2          | 7.9-8.1   | 7.9-8.2   | 7.9-8.1   | 7.9-8.2   | 7.6-8.0   |
| Total ammonia (start/end, mg L <sup>-1</sup> )           | 0.05/0.11                  | 0.07/0.13        | 1.13/1.06 | 2.46/1.15 | 5.24/3.41 | 10.8/8.31 | 24.5/18.2 |
| Total sulfide (start/end, mg L <sup>-1</sup> )           | <0.1                       | <0.1             | <0.1      | <0.1      | <0.1      | <0.1      | <0.1      |
| Total residual chlorine (start/end, mg L <sup>-1</sup> ) | <0.02                      | <0.02            | <0.02     | <0.02     | <0.02     | <0.02     | <0.02     |
| Total suspended solid (start/end, mg L <sup>-1</sup> )   | 3.9/4.3                    | 5.1/6.8          | 4.3/6.2   | 3.7/4.3   | 9.2/5.6   | 16.6/12.5 | 39.4/26.3 |

### 6.6. LC<sub>50</sub> for the shrimp *Metapenaeus ensis* and test acceptability

Table 4. LC<sub>50</sub> for the *Metapenaeus ensis* and test acceptability.

| Parameter                                          | Value                      | Control limit                              |
|----------------------------------------------------|----------------------------|--------------------------------------------|
| Calculated LC <sub>50</sub>                        | (68.9±2.4)%                | NA                                         |
| Negative control survival                          | 100%                       | >90%                                       |
| Reference toxicant 48-h acute test                 | 5.3 mg L <sup>-1</sup>     | 5.19±0.51 mg L <sup>-1</sup>               |
| 95% of confidence range of reference toxicant test | 4.4-6.1 mg L <sup>-1</sup> | NA                                         |
| Daily temperature variation                        | <0.5 °C                    | Average daily temperature variation: ±1 °C |
| Dissolved oxygen concentration                     | >6.3 mg L <sup>-1</sup>    | >4 mg L <sup>-1</sup>                      |

NA: Not applicable

## **7. Report on Copepod Acute Toxicity Test**

# Test report

## 7.1. Samples storage and pretreatment

Effluent sample was thoroughly mixed and passed through 5 µm membrane to remove the large debris. Effluent was added with ocean salt in order to raise the salinity to the required level (30‰) and then aerated moderately such that the dissolved oxygen (DO) reached saturation prior to use. Salinity control was set up to monitor if there was adverse effect on the test organisms.

## 7.2. Test organism

|                  |                                                                                                                                                                                |
|------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Species          | Copepod ( <i>Tigriopus japonicus</i> ).                                                                                                                                        |
| Source:          | Obtained from the laboratory cultures                                                                                                                                          |
| Size/age:        | Adult                                                                                                                                                                          |
| Acclimatization: | Acclimatized in fully aerated seawater (temperature: 22±1°C, salinity: 30‰) at least 48 hours in the laboratory prior to test. Fed with microalgae <i>Isochrysis galbana</i> . |

## 7.3. Summary of test conditions

|                                    |                                                                                 |
|------------------------------------|---------------------------------------------------------------------------------|
| Type of test:                      | Static                                                                          |
| Duration:                          | 48 h, 09/11/2015-11/11/2015                                                     |
| Dilution seawater source:          | Seawater collected from a pristine site in Clear Water Bay, Sai Kung, Hong Kong |
| Dilution seawater pretreatment:    | Filtered through 0.22 µm membrane                                               |
| Testing temperature:               | 22±1 °C                                                                         |
| Lighting:                          | Continuous                                                                      |
| Salinity:                          | 30‰                                                                             |
| Testing chamber:                   | Pre-cleaned 50 mL glass beaker                                                  |
| Feeding:                           | None                                                                            |
| Number of organisms per replicate: | 10                                                                              |
| Replicate number:                  | 4                                                                               |
| Volume of test medium:             | 20 mL                                                                           |
| Aeration:                          | Moderate shaking with shaker (15 rpm)                                           |
| Reference toxicant:                | CdCl <sub>2</sub>                                                               |
| Positive control:                  | 48 h acute toxicity test                                                        |
| Salinity control:                  | Prepared with ocean salt adding into de-ionized water, salinity: 30‰            |

#### 7.4. Test results

Table 1. Survival of copepods after 48 hours.

| Treatment        | Effluent concentration (%) | Number of living copepods after 48 hour (individuals) |             |             |             |      |     |
|------------------|----------------------------|-------------------------------------------------------|-------------|-------------|-------------|------|-----|
|                  |                            | Replicate 1                                           | Replicate 2 | Replicate 3 | Replicate 4 | Mean | SD  |
| Negative control | 0                          | 10                                                    | 10          | 10          | 10          | 10.0 | 0.0 |
| Salinity control | 0                          | 10                                                    | 10          | 9           | 10          | 9.8  | 0.5 |
| Concentration 1  | 6.5                        | 10                                                    | 10          | 10          | 10          | 10.0 | 0.0 |
| Concentration 2  | 12.5                       | 10                                                    | 10          | 9           | 10          | 9.8  | 0.5 |
| Concentration 3  | 25                         | 8                                                     | 9           | 8           | 10          | 8.8  | 1.0 |
| Concentration 4  | 50                         | 9                                                     | 8           | 7           | 7           | 7.8  | 1.0 |
| Concentration 5  | 100                        | 4                                                     | 4           | 4           | 5           | 4.3  | 0.5 |

Table 2. Survival percentage of copepods after 48 hours.

| Treatment        | Effluent concentration (%) | Percentage of living copepods after 48 hour (%) |             |             |             |       |     |
|------------------|----------------------------|-------------------------------------------------|-------------|-------------|-------------|-------|-----|
|                  |                            | Replicate 1                                     | Replicate 2 | Replicate 3 | Replicate 4 | Mean  | SD  |
| Negative control | 0                          | 100                                             | 100         | 100         | 100         | 100.0 | 0.0 |
| Salinity control | 0                          | 100                                             | 100         | 90          | 100         | 97.5  | 5.0 |
| Concentration 1  | 6.5                        | 100                                             | 100         | 100         | 100         | 100.0 | 0.0 |
| Concentration 2  | 12.5                       | 100                                             | 100         | 90          | 100         | 97.5  | 5.0 |
| Concentration 3  | 25                         | 80                                              | 90          | 80          | 100         | 87.5  | 9.6 |
| Concentration 4  | 50                         | 90                                              | 80          | 70          | 70          | 77.5  | 9.6 |
| Concentration 5  | 100                        | 40                                              | 40          | 40          | 50          | 42.5  | 5.0 |

**7.5. Summary of water quality parameters monitoring during test.**

Table 3. Summary of water quality parameters during copepod acute toxicity test.

| Water quality parameters                                 | Effluent concentration (%) |                  |           |           |           |           |           |
|----------------------------------------------------------|----------------------------|------------------|-----------|-----------|-----------|-----------|-----------|
|                                                          | Negative control           | Salinity control | 6.5       | 12.5      | 25        | 50        | 100       |
| Salinity (‰)                                             | 30.0                       | 30.0             | 30.0      | 30.0      | 30.0      | 30.0      | 30.0      |
| Dissolved oxygen (mg L <sup>-1</sup> )                   | 6.0-6.5                    | 6.1-6.4          | 6.1-6.5   | 6.1-6.3   | 6.0-6.4   | 6.1-6.4   | 6.0-6.4   |
| Temperature (°C)                                         | 22.0                       | 22.0             | 22.0      | 22.0      | 22.0      | 22.0      | 22.0      |
| pH                                                       | 8.0-8.2                    | 8.0-8.2          | 7.9-8.2   | 8.0-8.2   | 7.9-8.0   | 7.9-8.1   | 7.5-7.8   |
| Total ammonia (start/end, mg L <sup>-1</sup> )           | 0.05/0.05                  | 0.05/0.07        | 1.15/1.13 | 3.28/3.02 | 5.17/4.79 | 9.21/8.36 | 19.4/19.0 |
| Total sulfide (start/end, mg L <sup>-1</sup> )           | <0.1                       | <0.1             | <0.1      | <0.1      | <0.1      | <0.1      | <0.1      |
| Total residual chlorine (start/end, mg L <sup>-1</sup> ) | <0.02                      | <0.02            | <0.02     | <0.02     | <0.02     | <0.02     | <0.02     |
| Total suspended solid (start/end, mg L <sup>-1</sup> )   | <0.2                       | <0.2             | <0.2      | <0.2      | <0.2      | <0.2      | <0.2      |

**7.6. LC<sub>50</sub> for the copepod *Tigriopus japonicus* and test acceptability**

Table 4. LC<sub>50</sub> for the copepods and test acceptability.

| Parameter                                          | Value                      | Control limit                              |
|----------------------------------------------------|----------------------------|--------------------------------------------|
| Calculated LC <sub>50</sub>                        | (90.0±2.5)%                | NA                                         |
| Negative control survival                          | 100%                       | >90%                                       |
| Reference toxicant 48-h acute test                 | 5.2 mg L <sup>-1</sup>     | 4.37±0.44 mg L <sup>-1</sup>               |
| 95% of confidence range of reference toxicant test | 4.2-6.0 mg L <sup>-1</sup> | NA                                         |
| Daily temperature variation                        | <0.5 °C                    | Average daily temperature variation: ±1 °C |
| Dissolved oxygen concentration                     | >6.0 mg L <sup>-1</sup>    | >4 mg L <sup>-1</sup>                      |

NA: Not applicable

## **8. Conclusion**

Table 1. Comparison of measured toxicity values with the target toxicity levels.

| Test species                                 | Measured LC <sub>50</sub> /IC <sub>50</sub> /NOEC | Target toxicity level |
|----------------------------------------------|---------------------------------------------------|-----------------------|
| Amphipod<br><i>Melita longidactyla</i>       | 57.8%                                             | ≥7.1%                 |
| Fish<br><i>Lutjanus malabaricus</i>          | 80.5%                                             | ≥7.1%                 |
| Barnacle larvae<br><i>Balanus amphitrite</i> | 25.8%                                             | ≥7.1%                 |
| Diatom<br><i>Skeletonema costatum</i>        | 64.2% (IC <sub>50</sub> )                         | -                     |
| Diatom<br><i>Skeletonema costatum</i>        | 2.5% (NOEC)                                       | ≥0.51%                |
| Shrimp<br><i>Metapenaeus ensis</i>           | 68.9%                                             | ≥7.1%                 |
| Copepod<br><i>Tigriopus japonicus</i>        | 90.0%                                             | ≥7.1%                 |

Conclusion: all the measured values met the target toxicity levels as indicated in the EM&A Manual.

**Appendix A**

**Monitoring Data**  
**for**  
**Amphipod Acute Toxicity Test**



Table 1. Dissolved oxygen concentration and pH in each concentration treatment in amphipod acute toxicity test.

| Concentration treatment (%) | Dissolved oxygen (mg L <sup>-1</sup> ) |      |      |      |      | pH  |      |      |      |      |
|-----------------------------|----------------------------------------|------|------|------|------|-----|------|------|------|------|
|                             | 0 h                                    | 12 h | 24 h | 36 h | 48 h | 0 h | 12 h | 24 h | 36 h | 48 h |
| Negative control            | 6.5                                    | 6.0  | 6.3  | 6.8  | 6.4  | 7.9 | 8.0  | 8.2  | 8.1  | 8.1  |
| Salinity control            | 6.3                                    | 6.7  | 6.2  | 6.5  | 6.7  | 8.0 | 8.1  | 8.1  | 7.9  | 8.0  |
| 6.5                         | 6.0                                    | 6.6  | 7.0  | 6.7  | 6.7  | 8.1 | 7.9  | 7.9  | 8.0  | 8.0  |
| 12.5                        | 6.1                                    | 6.5  | 6.8  | 6.0  | 6.2  | 8.2 | 8.1  | 8.1  | 8.0  | 8.0  |
| 25                          | 6.8                                    | 6.2  | 7.0  | 6.9  | 6.0  | 8.0 | 8.1  | 8.0  | 8.1  | 8.1  |
| 50                          | 6.1                                    | 6.8  | 6.8  | 6.7  | 7.1  | 8.0 | 8.2  | 8.1  | 8.2  | 8.1  |
| 100                         | 6.6                                    | 6.3  | 6.4  | 6.1  | 6.3  | 7.7 | 7.6  | 7.6  | 8.1  | 7.8  |

Table 2. Salinity and temperature in each concentration treatment in amphipod acute toxicity test.

| Concentration treatment (%) | Salinity (‰) |      |      |      |      | Temperature (°C) |      |      |      |      |
|-----------------------------|--------------|------|------|------|------|------------------|------|------|------|------|
|                             | 0 h          | 12 h | 24 h | 36 h | 48 h | 0 h              | 12 h | 24 h | 36 h | 48 h |
| Negative control            | 30.0         | 30.0 | 30.0 | 30.0 | 30.0 | 22.0             | 22.0 | 22.0 | 22.0 | 22.0 |
| Salinity control            | 30.0         | 30.0 | 30.0 | 30.0 | 30.0 | 22.0             | 22.0 | 22.0 | 22.0 | 22.0 |
| 6.5                         | 30.0         | 30.0 | 30.0 | 30.0 | 30.0 | 22.0             | 22.0 | 22.0 | 22.0 | 22.0 |
| 12.5                        | 30.0         | 30.0 | 30.0 | 30.0 | 30.0 | 22.0             | 22.0 | 22.0 | 22.0 | 22.0 |
| 25                          | 30.0         | 30.0 | 30.0 | 30.0 | 30.0 | 22.0             | 22.0 | 22.0 | 22.0 | 22.0 |
| 50                          | 30.0         | 30.0 | 30.0 | 30.0 | 30.0 | 22.0             | 22.0 | 22.0 | 22.0 | 22.0 |
| 100                         | 30.0         | 30.0 | 30.0 | 30.0 | 30.0 | 22.0             | 22.0 | 22.0 | 22.0 | 22.0 |

Table 3. Ammonia-N, sulphide, total suspended solids, total residual chlorine concentration at the beginning and ending of the amphipod acute toxicity test.

| Concentration<br>treatment<br>(%) | Ammonia-N<br>(mg L <sup>-1</sup> ) |      | Sulphide<br>(mg L <sup>-1</sup> ) |      | Total suspended solids<br>(mg L <sup>-1</sup> ) |      | Total residual chlorine<br>(mg L <sup>-1</sup> ) |       |
|-----------------------------------|------------------------------------|------|-----------------------------------|------|-------------------------------------------------|------|--------------------------------------------------|-------|
|                                   | Initial                            | End  | Initial                           | End  | Initial                                         | End  | Initial                                          | End   |
| Negative control                  | 0.06                               | 0.31 | <0.1                              | <0.1 | 4.1                                             | 3.5  | <0.02                                            | <0.02 |
| Salinity control                  | 0.05                               | 0.15 | <0.1                              | <0.1 | 3.6                                             | 4.6  | <0.02                                            | <0.02 |
| 6.5                               | 0.93                               | 0.56 | <0.1                              | <0.1 | 4.1                                             | 5.1  | <0.02                                            | <0.02 |
| 12.5                              | 2.16                               | 1.68 | <0.1                              | <0.1 | 6.8                                             | 5.2  | <0.02                                            | <0.02 |
| 25                                | 4.32                               | 4.01 | <0.1                              | <0.1 | 13.4                                            | 7.6  | <0.02                                            | <0.02 |
| 50                                | 9.62                               | 7.82 | <0.1                              | <0.1 | 20.7                                            | 16.5 | <0.02                                            | <0.02 |
| 100                               | 21.3                               | 16.3 | <0.1                              | <0.1 | 44.6                                            | 36.2 | <0.02                                            | <0.02 |

**Appendix B**

**Monitoring Data  
for  
Fish Acute Toxicity Test**

Table 1. Dissolved oxygen concentration and pH in each concentration treatment in fish acute toxicity test.

| Concentration treatment (%) | Dissolved oxygen (mg L <sup>-1</sup> ) |      |      |      |      | pH  |      |      |      |      |
|-----------------------------|----------------------------------------|------|------|------|------|-----|------|------|------|------|
|                             | 0 h                                    | 12 h | 24 h | 36 h | 48 h | 0 h | 12 h | 24 h | 36 h | 48 h |
| Negative control            | 6.3                                    | 6.8  | 7.2  | 7.1  | 6.6  | 8.1 | 8.0  | 8.1  | 7.9  | 8.0  |
| Salinity control            | 7.0                                    | 6.7  | 6.2  | 7.0  | 6.8  | 8.1 | 8.1  | 8.1  | 8.2  | 8.0  |
| 6.5                         | 6.3                                    | 7.2  | 6.2  | 6.5  | 6.8  | 8.0 | 7.9  | 7.9  | 8.0  | 7.9  |
| 12.5                        | 7.1                                    | 6.2  | 6.6  | 6.8  | 6.8  | 8.1 | 8.2  | 7.9  | 8.2  | 8.2  |
| 25                          | 6.8                                    | 6.3  | 6.7  | 6.7  | 7.1  | 8.1 | 7.9  | 8.0  | 8.0  | 8.2  |
| 50                          | 6.6                                    | 6.7  | 6.8  | 7.2  | 6.4  | 8.0 | 8.1  | 8.1  | 8.0  | 8.0  |
| 100                         | 7.1                                    | 6.4  | 6.9  | 6.8  | 7.0  | 7.9 | 8.0  | 7.8  | 7.8  | 7.6  |

Table 2. Salinity and temperature in each concentration treatment in fish acute toxicity test.

| Concentration treatment (%) | Salinity (‰) |      |      |      |      | Temperature (°C) |      |      |      |      |
|-----------------------------|--------------|------|------|------|------|------------------|------|------|------|------|
|                             | 0 h          | 12 h | 24 h | 36 h | 48 h | 0 h              | 12 h | 24 h | 36 h | 48 h |
| Negative control            | 30.0         | 30.0 | 30.0 | 30.0 | 30.0 | 22.0             | 22.0 | 22.0 | 22.0 | 22.0 |
| Salinity control            | 30.0         | 30.0 | 30.0 | 30.0 | 30.0 | 22.0             | 22.0 | 22.0 | 22.0 | 22.0 |
| 6.5                         | 30.0         | 30.0 | 30.0 | 30.0 | 30.0 | 22.0             | 22.0 | 22.0 | 22.0 | 22.0 |
| 12.5                        | 30.0         | 30.0 | 30.0 | 30.0 | 30.0 | 22.0             | 22.0 | 22.0 | 22.0 | 22.0 |
| 25                          | 30.0         | 30.0 | 30.0 | 30.0 | 30.0 | 22.0             | 22.0 | 22.0 | 22.0 | 22.0 |
| 50                          | 30.0         | 30.0 | 30.0 | 30.0 | 30.0 | 22.0             | 22.0 | 22.0 | 22.0 | 22.0 |
| 100                         | 30.0         | 30.0 | 30.0 | 30.0 | 30.0 | 22.0             | 22.0 | 22.0 | 22.0 | 22.0 |

Table 3. Ammonia-N, sulphide, total suspended solids, total residual chlorine concentration at the beginning and ending of the fish acute toxicity test.

| Concentration treatment (%) | Ammonia-N (mg L <sup>-1</sup> ) |      | Sulphide (mg L <sup>-1</sup> ) |      | Total suspended solids (mg L <sup>-1</sup> ) |      | Total residual chlorine (mg L <sup>-1</sup> ) |       |
|-----------------------------|---------------------------------|------|--------------------------------|------|----------------------------------------------|------|-----------------------------------------------|-------|
|                             | Initial                         | End  | Initial                        | End  | Initial                                      | End  | Initial                                       | End   |
| Negative control            | 0.08                            | 0.15 | <0.1                           | <0.1 | 4.0                                          | 5.1  | <0.02                                         | <0.02 |
| Salinity control            | 0.06                            | 0.13 | <0.1                           | <0.1 | 5.1                                          | 3.9  | <0.02                                         | <0.02 |
| 6.5                         | 1.51                            | 1.22 | <0.1                           | <0.1 | 7.1                                          | 7.6  | <0.02                                         | <0.02 |
| 12.5                        | 2.43                            | 2.06 | <0.1                           | <0.1 | 6.9                                          | 8.1  | <0.02                                         | <0.02 |
| 25                          | 5.87                            | 4.21 | <0.1                           | <0.1 | 10.2                                         | 8.2  | <0.02                                         | <0.02 |
| 50                          | 10.9                            | 8.2  | <0.1                           | <0.1 | 17.4                                         | 13.8 | <0.02                                         | <0.02 |
| 100                         | 23.8                            | 20.3 | <0.1                           | <0.1 | 38.9                                         | 19.1 | <0.02                                         | <0.02 |

**Appendix C**

**Monitoring Data**  
**for**  
**Barnacle Larvae Acute Toxicity Test**

Table 1. Dissolved oxygen concentration and pH in each concentration treatment in barnacle larvae acute toxicity test.

| Concentration treatment (%) | Dissolved oxygen (mg L <sup>-1</sup> ) |      |      |      |      | pH  |      |      |      |      |
|-----------------------------|----------------------------------------|------|------|------|------|-----|------|------|------|------|
|                             | 0 h                                    | 12 h | 24 h | 36 h | 48 h | 0 h | 12 h | 24 h | 36 h | 48 h |
| Negative control            | 6.4                                    | 6.6  | 6.2  | 6.6  | 6.5  | 8.1 | 8.0  | 8.2  | 8.1  | 8.1  |
| Salinity control            | 6.6                                    | 6.6  | 6.2  | 6.6  | 6.5  | 8.0 | 8.1  | 8.1  | 8.0  | 8.1  |
| 6.5                         | 6.2                                    | 6.6  | 6.5  | 6.6  | 6.6  | 8.2 | 8.2  | 8.2  | 8.1  | 8.1  |
| 12.5                        | 6.4                                    | 6.3  | 6.4  | 6.5  | 6.6  | 8.2 | 7.9  | 8.1  | 7.9  | 8.0  |
| 25                          | 6.5                                    | 6.6  | 6.5  | 6.6  | 6.4  | 7.9 | 8.2  | 8.1  | 8.2  | 7.9  |
| 50                          | 6.4                                    | 6.2  | 6.5  | 6.2  | 6.3  | 8.1 | 8.1  | 8.2  | 8.1  | 8.0  |
| 100                         | 6.6                                    | 6.5  | 6.6  | 6.2  | 6.2  | 7.7 | 7.9  | 7.8  | 7.6  | 7.7  |

Table 2. Salinity and temperature in each concentration treatment in barnacle larvae acute toxicity test.

| Concentration treatment (%) | Salinity (‰) |      |      |      |      | Temperature (°C) |      |      |      |      |
|-----------------------------|--------------|------|------|------|------|------------------|------|------|------|------|
|                             | 0 h          | 12 h | 24 h | 36 h | 48 h | 0 h              | 12 h | 24 h | 36 h | 48 h |
| Negative control            | 30.0         | 30.0 | 30.0 | 30.0 | 30.0 | 22.0             | 22.0 | 22.0 | 22.0 | 22.0 |
| Salinity control            | 30.0         | 30.0 | 30.0 | 30.0 | 30.0 | 22.0             | 22.0 | 22.0 | 22.0 | 22.0 |
| 6.5                         | 30.0         | 30.0 | 30.0 | 30.0 | 30.0 | 22.0             | 22.0 | 22.0 | 22.0 | 22.0 |
| 12.5                        | 30.0         | 30.0 | 30.0 | 30.0 | 30.0 | 22.0             | 22.0 | 22.0 | 22.0 | 22.0 |
| 25                          | 30.0         | 30.0 | 30.0 | 30.0 | 30.0 | 22.0             | 22.0 | 22.0 | 22.0 | 22.0 |
| 50                          | 30.0         | 30.0 | 30.0 | 30.0 | 30.0 | 22.0             | 22.0 | 22.0 | 22.0 | 22.0 |
| 100                         | 30.0         | 30.0 | 30.0 | 30.0 | 30.0 | 22.0             | 22.0 | 22.0 | 22.0 | 22.0 |

Table 3. Ammonia-N, sulphide, total suspended solids, total residual chlorine concentration at the beginning and ending of the barnacle larvae acute toxicity test.

| Concentration<br>treatment<br>(%) | Ammonia-N<br>(mg L <sup>-1</sup> ) |      | Sulphide<br>(mg L <sup>-1</sup> ) |      | Total suspended solids<br>(mg L <sup>-1</sup> ) |      | Total residual chlorine<br>(mg L <sup>-1</sup> ) |       |
|-----------------------------------|------------------------------------|------|-----------------------------------|------|-------------------------------------------------|------|--------------------------------------------------|-------|
|                                   | Initial                            | End  | Initial                           | End  | Initial                                         | End  | Initial                                          | End   |
| Negative control                  | 0.06                               | 0.02 | <0.1                              | <0.1 | <0.2                                            | <0.2 | <0.02                                            | <0.02 |
| Salinity control                  | 0.06                               | 0.07 | <0.1                              | <0.1 | <0.2                                            | <0.2 | <0.02                                            | <0.02 |
| 6.5                               | 1.54                               | 1.21 | <0.1                              | <0.1 | <0.2                                            | <0.2 | <0.02                                            | <0.02 |
| 12.5                              | 2.27                               | 2.08 | <0.1                              | <0.1 | <0.2                                            | <0.2 | <0.02                                            | <0.02 |
| 25                                | 4.94                               | 4.22 | <0.1                              | <0.1 | <0.2                                            | <0.2 | <0.02                                            | <0.02 |
| 50                                | 10.6                               | 10.2 | <0.1                              | <0.1 | <0.2                                            | <0.2 | <0.02                                            | <0.02 |
| 100                               | 21.1                               | 20.9 | <0.1                              | <0.1 | <0.2                                            | <0.2 | <0.02                                            | <0.02 |



**Appendix D**

**Monitoring Data**  
**for**  
**Diatom Growth Inhibition Test**  
**(Chronic toxicity test)**

Table 1. Dissolved oxygen concentration and pH in each concentration treatment in diatom growth inhibition test.

| Concentration treatment (%) | Dissolved oxygen (mg L <sup>-1</sup> ) |      |      |      |      |       |       |       | pH  |      |      |      |      |       |       |       |
|-----------------------------|----------------------------------------|------|------|------|------|-------|-------|-------|-----|------|------|------|------|-------|-------|-------|
|                             | 0 h                                    | 24 h | 48 h | 72 h | 96 h | 120 h | 144 h | 168 h | 0 h | 24 h | 48 h | 72 h | 96 h | 120 h | 144 h | 168 h |
| Negative control            | 6.3                                    | 6.4  | 6.9  | 7.6  | 8.7  | 9.1   | 9.3   | 8.4   | 8.0 | 7.9  | 8.4  | 8.3  | 8.2  | 8.6   | 8.3   | 8.4   |
| Salinity control            | 6.5                                    | 6.6  | 6.8  | 8.2  | 8.3  | 8.9   | 10.2  | 9.2   | 7.9 | 7.9  | 8.6  | 8.4  | 8.4  | 8.4   | 8.6   | 8.8   |
| 2.5                         | 6.4                                    | 6.4  | 6.9  | 8.4  | 8.4  | 8.6   | 9.5   | 10.1  | 8.0 | 8.0  | 8.4  | 8.3  | 8.4  | 8.5   | 8.5   | 8.5   |
| 5                           | 6.5                                    | 6.6  | 7.1  | 8.5  | 8.9  | 9.2   | 9.8   | 9.3   | 8.0 | 8.2  | 8.5  | 8.2  | 8.5  | 8.7   | 8.2   | 9.0   |
| 10                          | 6.6                                    | 6.6  | 6.9  | 8.2  | 8.5  | 9.7   | 10.1  | 9.4   | 8.0 | 8.1  | 8.6  | 8.6  | 8.4  | 8.6   | 8.8   | 8.5   |
| 25                          | 6.5                                    | 6.5  | 6.8  | 8.3  | 8.4  | 8.6   | 9.5   | 9.2   | 8.1 | 8.2  | 8.7  | 8.5  | 8.3  | 8.5   | 8.7   | 8.5   |
| 50                          | 6.6                                    | 6.4  | 6.8  | 7.4  | 7.6  | 8.8   | 8.3   | 8.8   | 8.0 | 8.2  | 8.4  | 8.0  | 8.4  | 8.5   | 8.5   | 8.7   |
| 100                         | 6.5                                    | 6.2  | 6.3  | 6.0  | 6.5  | 6.8   | 6.2   | 7.2   | 8.0 | 7.9  | 8.1  | 8.0  | 7.6  | 7.8   | 7.9   | 7.8   |

Table 2. Salinity and temperature in each concentration treatment in diatom growth inhibition test.

| Concentration treatment (%) | Salinity (‰) |      |      |      |      |       |       |       | Temperature (°C) |      |      |      |      |       |       |       |
|-----------------------------|--------------|------|------|------|------|-------|-------|-------|------------------|------|------|------|------|-------|-------|-------|
|                             | 0 h          | 24 h | 48 h | 72 h | 96 h | 120 h | 144 h | 168 h | 0 h              | 24 h | 48 h | 72 h | 96 h | 120 h | 144 h | 168 h |
| Negative control            | 30.0         | 30.0 | 30.0 | 30.0 | 30.0 | 30.0  | 30.0  | 30.0  | 22.0             | 22.0 | 22.0 | 22.0 | 22.0 | 22.0  | 22.0  | 22.0  |
| Salinity control            | 30.0         | 30.0 | 30.0 | 30.0 | 30.0 | 30.0  | 30.0  | 30.0  | 22.0             | 22.0 | 22.0 | 22.0 | 22.0 | 22.0  | 22.0  | 22.0  |
| 2.5                         | 30.0         | 30.0 | 30.0 | 30.0 | 30.0 | 30.0  | 30.0  | 30.0  | 22.0             | 22.0 | 22.0 | 22.0 | 22.0 | 22.0  | 22.0  | 22.0  |
| 5                           | 30.0         | 30.0 | 30.0 | 30.0 | 30.0 | 30.0  | 30.0  | 30.0  | 22.0             | 22.0 | 22.0 | 22.0 | 22.0 | 22.0  | 22.0  | 22.0  |
| 10                          | 30.0         | 30.0 | 30.0 | 30.0 | 30.0 | 30.0  | 30.0  | 30.0  | 22.0             | 22.0 | 22.0 | 22.0 | 22.0 | 22.0  | 22.0  | 22.0  |
| 25                          | 30.0         | 30.0 | 30.0 | 30.0 | 30.0 | 30.0  | 30.0  | 30.0  | 22.0             | 22.0 | 22.0 | 22.0 | 22.0 | 22.0  | 22.0  | 22.0  |
| 50                          | 30.0         | 30.0 | 30.0 | 30.0 | 30.0 | 30.0  | 30.0  | 30.0  | 22.0             | 22.0 | 22.0 | 22.0 | 22.0 | 22.0  | 22.0  | 22.0  |
| 100                         | 30.0         | 30.0 | 30.0 | 30.0 | 30.0 | 30.0  | 30.0  | 30.0  | 22.0             | 22.0 | 22.0 | 22.0 | 22.0 | 22.0  | 22.0  | 22.0  |

Table 3. Ammonia-N, sulphide, total suspended solids, total residual chlorine concentration at the beginning and ending of the diatom growth inhibition toxicity test.

| Concentration treatment (%) | Ammonia-N (mg L <sup>-1</sup> ) |      | Sulphide (mg L <sup>-1</sup> ) |      | Total suspended solids (mg L <sup>-1</sup> ) |      | Total residual chlorine (mg L <sup>-1</sup> ) |       |
|-----------------------------|---------------------------------|------|--------------------------------|------|----------------------------------------------|------|-----------------------------------------------|-------|
|                             | Initial                         | End  | Initial                        | End  | Initial                                      | End  | Initial                                       | End   |
| Negative control            | 0.09                            | 0.06 | <0.1                           | <0.1 | <0.2                                         | <0.2 | <0.02                                         | <0.02 |
| Salinity control            | 0.07                            | 0.05 | <0.1                           | <0.1 | <0.2                                         | <0.2 | <0.02                                         | <0.02 |
| 2.5                         | 0.36                            | 0.08 | <0.1                           | <0.1 | <0.2                                         | <0.2 | <0.02                                         | <0.02 |
| 5                           | 1.09                            | 0.09 | <0.1                           | <0.1 | <0.2                                         | <0.2 | <0.02                                         | <0.02 |
| 10                          | 2.28                            | 0.13 | <0.1                           | <0.1 | <0.2                                         | <0.2 | <0.02                                         | <0.02 |
| 25                          | 4.44                            | 0.21 | <0.1                           | <0.1 | <0.2                                         | <0.2 | <0.02                                         | <0.02 |
| 50                          | 9.92                            | 7.67 | <0.1                           | <0.1 | <0.2                                         | <0.2 | <0.02                                         | <0.02 |
| 100                         | 18.7                            | 17.2 | <0.1                           | <0.1 | <0.2                                         | <0.2 | <0.02                                         | <0.02 |

**Appendix E**

**Monitoring Data**  
**for**  
**Shrimp Acute Toxicity Test**

Table 1. Dissolved oxygen concentration and pH in each concentration treatment in shrimp acute toxicity test.

| Concentration treatment (%) | Dissolved oxygen (mg L <sup>-1</sup> ) |      |      |      |      | pH  |      |      |      |      |
|-----------------------------|----------------------------------------|------|------|------|------|-----|------|------|------|------|
|                             | 0 h                                    | 12 h | 24 h | 36 h | 48 h | 0 h | 12 h | 24 h | 36 h | 48 h |
| Negative control            | 6.5                                    | 7.2  | 6.7  | 7.0  | 6.3  | 7.9 | 7.9  | 8.1  | 7.9  | 8.0  |
| Salinity control            | 6.3                                    | 7.1  | 6.5  | 6.9  | 6.6  | 8.2 | 7.9  | 8.1  | 8.0  | 8.0  |
| 6.5                         | 6.5                                    | 6.7  | 6.7  | 7.3  | 7.0  | 8.1 | 8.0  | 8.1  | 8.0  | 7.9  |
| 12.5                        | 6.5                                    | 6.7  | 7.1  | 7.2  | 7.2  | 8.2 | 7.9  | 7.9  | 8.0  | 8.2  |
| 25                          | 7.0                                    | 6.3  | 6.3  | 7.1  | 6.9  | 8.0 | 8.1  | 7.9  | 8.0  | 8.1  |
| 50                          | 7.3                                    | 6.9  | 7.3  | 6.9  | 6.8  | 7.9 | 8.1  | 8.1  | 8.0  | 8.2  |
| 100                         | 7.1                                    | 6.8  | 7.3  | 7.1  | 6.5  | 7.8 | 7.6  | 7.7  | 8.0  | 7.7  |

Table 2. Salinity and temperature in each concentration treatment in shrimp acute toxicity test.

| Concentration treatment (%) | Salinity (‰) |      |      |      |      | Temperature (°C) |      |      |      |      |
|-----------------------------|--------------|------|------|------|------|------------------|------|------|------|------|
|                             | 0 h          | 12 h | 24 h | 36 h | 48 h | 0 h              | 12 h | 24 h | 36 h | 48 h |
| Negative control            | 25.0         | 25.0 | 25.0 | 25.0 | 25.0 | 22.0             | 22.0 | 22.0 | 22.0 | 22.0 |
| Salinity control            | 25.0         | 25.0 | 25.0 | 25.0 | 25.0 | 22.0             | 22.0 | 22.0 | 22.0 | 22.0 |
| 6.5                         | 25.0         | 25.0 | 25.0 | 25.0 | 25.0 | 22.0             | 22.0 | 22.0 | 22.0 | 22.0 |
| 12.5                        | 25.0         | 25.0 | 25.0 | 25.0 | 25.0 | 22.0             | 22.0 | 22.0 | 22.0 | 22.0 |
| 25                          | 25.0         | 25.0 | 25.0 | 25.0 | 25.0 | 22.0             | 22.0 | 22.0 | 22.0 | 22.0 |
| 50                          | 25.0         | 25.0 | 25.0 | 25.0 | 25.0 | 22.0             | 22.0 | 22.0 | 22.0 | 22.0 |
| 100                         | 25.0         | 25.0 | 25.0 | 25.0 | 25.0 | 22.0             | 22.0 | 22.0 | 22.0 | 22.0 |

Table 3. Ammonia-N, sulphide, total suspended solids, total residual chlorine concentration at the beginning and ending of the shrimp acute toxicity test.

| Concentration treatment (%) | Ammonia-N (mg L <sup>-1</sup> ) |      | Sulphide (mg L <sup>-1</sup> ) |      | Total suspended solids (mg L <sup>-1</sup> ) |      | Total residual chlorine (mg L <sup>-1</sup> ) |       |
|-----------------------------|---------------------------------|------|--------------------------------|------|----------------------------------------------|------|-----------------------------------------------|-------|
|                             | Initial                         | End  | Initial                        | End  | Initial                                      | End  | Initial                                       | End   |
| Negative control            | 0.05                            | 0.11 | <0.1                           | <0.1 | 3.9                                          | 4.3  | <0.02                                         | <0.02 |
| Salinity control            | 0.07                            | 0.13 | <0.1                           | <0.1 | 5.1                                          | 6.8  | <0.02                                         | <0.02 |
| 6.5                         | 1.13                            | 1.06 | <0.1                           | <0.1 | 4.3                                          | 6.2  | <0.02                                         | <0.02 |
| 12.5                        | 2.46                            | 1.15 | <0.1                           | <0.1 | 3.7                                          | 4.3  | <0.02                                         | <0.02 |
| 25                          | 5.24                            | 3.41 | <0.1                           | <0.1 | 9.2                                          | 5.6  | <0.02                                         | <0.02 |
| 50                          | 10.8                            | 8.31 | <0.1                           | <0.1 | 16.6                                         | 12.5 | <0.02                                         | <0.02 |
| 100                         | 24.5                            | 18.2 | <0.1                           | <0.1 | 39.4                                         | 26.3 | <0.02                                         | <0.02 |

**Appendix F**

**Monitoring Data**  
**for**  
**Copepod Acute Toxicity Test**



Table 1. Dissolved oxygen concentration and pH in each concentration treatment in copepod acute toxicity test.

| Concentration treatment (%) | Dissolved oxygen (mg L <sup>-1</sup> ) |      |      |      |      | pH  |      |      |      |      |
|-----------------------------|----------------------------------------|------|------|------|------|-----|------|------|------|------|
|                             | 0 h                                    | 12 h | 24 h | 36 h | 48 h | 0 h | 12 h | 24 h | 36 h | 48 h |
| Negative control            | 6.3                                    | 6.1  | 6.0  | 6.4  | 6.5  | 8.0 | 8.2  | 8.1  | 8.2  | 8.0  |
| Salinity control            | 6.2                                    | 6.1  | 6.2  | 6.4  | 6.3  | 8.0 | 8.0  | 7.9  | 8.2  | 8.0  |
| 6.5                         | 6.2                                    | 6.5  | 6.1  | 6.5  | 6.1  | 7.9 | 8.0  | 8.2  | 8.2  | 8.1  |
| 12.5                        | 6.3                                    | 6.1  | 6.1  | 6.3  | 6.3  | 8.2 | 7.9  | 8.1  | 7.9  | 8.0  |
| 25                          | 6.4                                    | 6.2  | 6.3  | 6.1  | 6.0  | 7.9 | 8.0  | 7.9  | 8.0  | 7.9  |
| 50                          | 6.2                                    | 6.1  | 6.2  | 6.1  | 6.4  | 8.1 | 7.9  | 8.0  | 8.1  | 7.9  |
| 100                         | 6.4                                    | 6.0  | 6.0  | 6.3  | 6.0  | 7.7 | 7.8  | 7.8  | 7.6  | 7.5  |

Table 2. Salinity and temperature in each concentration treatment in copepod acute toxicity test.

| Concentration treatment (%) | Salinity (‰) |      |      |      |      | Temperature (°C) |      |      |      |      |
|-----------------------------|--------------|------|------|------|------|------------------|------|------|------|------|
|                             | 0 h          | 12 h | 24 h | 36 h | 48 h | 0 h              | 12 h | 24 h | 36 h | 48 h |
| Negative control            | 30.0         | 30.0 | 30.0 | 30.0 | 30.0 | 22.0             | 22.0 | 22.0 | 22.0 | 22.0 |
| Salinity control            | 30.0         | 30.0 | 30.0 | 30.0 | 30.0 | 22.0             | 22.0 | 22.0 | 22.0 | 22.0 |
| 6.5                         | 30.0         | 30.0 | 30.0 | 30.0 | 30.0 | 22.0             | 22.0 | 22.0 | 22.0 | 22.0 |
| 12.5                        | 30.0         | 30.0 | 30.0 | 30.0 | 30.0 | 22.0             | 22.0 | 22.0 | 22.0 | 22.0 |
| 25                          | 30.0         | 30.0 | 30.0 | 30.0 | 30.0 | 22.0             | 22.0 | 22.0 | 22.0 | 22.0 |
| 50                          | 30.0         | 30.0 | 30.0 | 30.0 | 30.0 | 22.0             | 22.0 | 22.0 | 22.0 | 22.0 |
| 100                         | 30.0         | 30.0 | 30.0 | 30.0 | 30.0 | 22.0             | 22.0 | 22.0 | 22.0 | 22.0 |

Table 3. Ammonia-N, sulphide, total suspended solids, total residual chlorine concentration at the beginning and ending of the copepod acute toxicity test.

| Concentration treatment (%) | Ammonia-N (mg L <sup>-1</sup> ) |      | Sulphide (mg L <sup>-1</sup> ) |      | Total suspended solids (mg L <sup>-1</sup> ) |      | Total residual chlorine (mg L <sup>-1</sup> ) |       |
|-----------------------------|---------------------------------|------|--------------------------------|------|----------------------------------------------|------|-----------------------------------------------|-------|
|                             | Initial                         | End  | Initial                        | End  | Initial                                      | End  | Initial                                       | End   |
| Negative control            | 0.05                            | 0.05 | <0.1                           | <0.1 | <0.2                                         | <0.2 | <0.02                                         | <0.02 |
| Salinity control            | 0.05                            | 0.07 | <0.1                           | <0.1 | <0.2                                         | <0.2 | <0.02                                         | <0.02 |
| 6.5                         | 1.15                            | 1.13 | <0.1                           | <0.1 | <0.2                                         | <0.2 | <0.02                                         | <0.02 |
| 12.5                        | 3.28                            | 3.02 | <0.1                           | <0.1 | <0.2                                         | <0.2 | <0.02                                         | <0.02 |
| 25                          | 5.17                            | 4.79 | <0.1                           | <0.1 | <0.2                                         | <0.2 | <0.02                                         | <0.02 |
| 50                          | 9.21                            | 8.36 | <0.1                           | <0.1 | <0.2                                         | <0.2 | <0.02                                         | <0.02 |
| 100                         | 19.4                            | 19.0 | <0.1                           | <0.1 | <0.2                                         | <0.2 | <0.02                                         | <0.02 |