

Interim Notifications of Environmental Quality Limits Exceedances


Incident Report on Action Level or Limit Level Non-compliance

Project	Tsuen Wan Drainage Tunnel
Date	17-Nov-08
Time	9:40 AM
Monitoring Location	Sik Sik Yuen Ho Fung College (I-1)
Parameter	Suspended Solid
Action & Limit Levels	8.85 / 10.17
Measured Level	7.0 (higher than 130% of control station's SS)
Possible reason for Action or Limit Level Non-compliance	A low SS level of 4.0 is recorded at Control Station (I-1-C)
Actions taken / to be taken	No action is taken as the monitoring result was well below both Baseline Action & Baseline Limit Levels and no direct disturbance was observed contributed by project construction activities including site tidiness, drilling temporary pipe pile for spiral ramp construction. No exceedance was recorded for the subsequence measurement performed on 19/11/2008.
Remarks	The control limit level exceedance is considered not project-related.

Prepared by: Desmond Chan

Designation: Senior Environmental Consultant

Signature:



Date: 25-Nov-08

Photographic record for exceedance of Suspended Solid recorded at Sik Sik Yuen Ho Fung College (I-1) on 17-Nov-08



Interim Notifications of Environmental Quality Limits Exceedances


Incident Report on Action Level or Limit Level Non-compliance

Project	Tsuen Wan Drainage Tunnel
Date	27-Nov-08
Time	1:30 PM
Monitoring Location	Greenview Terrace (ASR9)
Parameter	Total Suspended Particulate
Action & Limit Levels	329.2 / 500
Measured Level	376
Possible reason for Action or Limit Level Non-compliance	Fugitive dust generated from tree logging and site tidiness was observed during the measurement of 1st 1hr TSP monitoring.
Actions taken / to be taken	Contractor was requested to provide water spraying for dust suppression. Water spraying was immediately provided by Contractor. The consequent monitoring results (2nd, 169.5ug/m3 and 3rd, 135.1 ug/m3) were below Action and Limit Level. The recommended dust suppression measures were effective.
Remarks	Nil

Prepared by: Desmond Chan

Designation: Senior Environmental Consultant

Signature:



Date: 4-Dec-08

Photographic record for exceedance of Total Suspended Particulate recorded at Greenview Terrace (ASR9) on 27-Nov-08

